

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :

ISO 9001 : 2015

ISO 14001 : 2015

ISO 45001 : 2018

TEST REPORT					
Report No.	NLES/25-26/11/ST/RE/754	Report Issue Date	25/11/2025		
Name and Address of Customer	M/S. EMCURE PHARMACEUTICALS LTD., Plot No. 12/2, F 2 Block, MIDC, Pimpri, Pune - 411 018				
Group	Atmospheric Pollution				
Sub Group	Noise				
Sample Name	DG Insertion Loss Monitoring				
Date of Sampling	18/11/2025				
Method of Sampling	IS 9989: 1981				
Sampling done by	M/s VSK Enviro Solution				
Results					
Sr. No.	Description	Test Location	Unit	Reading dB(A)	Insertion loss
1	D. G. Set 1010 KVA (D.G-204)	Inside Acoustic Enclosure	dB(A)	107.1	28.7
		Outside Acoustic Closure From 0.5 meter away	dB(A)	78.4	
Remark- Maharashtra Pollution Control Board has prescribed in consent, acoustic enclosure/ acoustic treatment of the room should be designed for minimum 25 dB (A) insertion loss or for meeting the ambient noise standard, whichever is on higher side.					

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Page 1 of 1

Reviewed by
AB
01.12.25