

**Neetal Laboratories And Environmental Services Pvt. Ltd.**

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :  
ISO 9001 : 2015  
ISO 14001 : 2015  
ISO 45001 : 2018

TEST REPORT					
Report No:	NLES/25-26/11/WW/RE/659	Issue Date	10/11/2025		
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot No. 12/2, F 2 Block, MIDC, Pimpri, Pune - 411 018				
Discipline	Chemical	Date of Sample Collection	03/11/2025		
Sub Group	Waste Water	Sample Quantity	02 Liter Plastic can + 1000 ml Glass Bottle		
Sample Description	ETP Outlet	Sample Status	Sealed		
Sample collected by	M/s VSK Enviro Solution				
Start Date of Analysis	04/11/2025	End Date of Analysis	10/11/2025		
Results					
Sr. No.	Parameters	Results	Unit(s)	MPCB Limits	Methods
1	pH at 25°C	7.38	-	6.0-8.5	APHA 4500, H+, B: 24th Ed.2023
2	Total Suspended Solids (TSS)	11.0	mg/l	<100	APHA2540, D, 24th Ed. 2023
3	Total Dissolve Solids	391.0	mg/l	<2100	APHA-2540-D,24th Ed.2023
4	Chemical Oxygen Demand	29.4	mg/l	<250	IS 3025 (Part 58), 2006
5	Biochemical Oxygen Demand (BOD) 3 days at 27°C	10.0	mg/l	<30	IS 3025 (Part 44), 2019
6	Chloride (as Cl)	46.0	mg/l	<600	IS 3025 (Part 32 ), 2019
7	Sulphate (as SO <sub>4</sub> )	19.0	mg/l	<1000	APHA 4500 SO <sub>4</sub> , E, 24th Ed. 2023
8	Oil & Grease (O & G)	BDL	mg/l	<10	IS 3025 (Part 39), Method (a), 2021
9	Phosphate	BDL	mg/l	NS	APHA 24th Ed,4500-P D
10	Ammoniacal Nitrogen as NH <sub>3</sub> -N	<0.08	mg/l	NS	APHA 24th Ed., 4500-NH <sub>3</sub> °C
11	Bioassay Test	93 % Survival of fish after 24 hours in 100 % effluent		NS	APHA 24th Ed., 10600
Remark-The above results are within MPCB Limits. <b>NS – Not Specified. BDL- Below detection Limit.</b>					

## Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

*Kalyani*  
Reviewed By  
(Ms. Kalyani Gore)



*Abhishek*  
Authorized Signatory  
(Mr. Abhishek Tope)

\*\*\*\*\*End of Report\*\*\*\*\*

Page 1 of 1

Reviewed by  
*ABJ*  
01.12.25