

**Neetal Laboratories And Environmental Services Pvt. Ltd.**

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501  
 Website : www.neetalenvirolab.com, Mob. 8669699854 / 52  
 Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :  
 ISO 9001 : 2015  
 ISO 14001 : 2015  
 ISO 45001 : 2018

| TEST REPORT (Stack Emission)   |   |                      |  |                               |                        |
|--|---|----------------------|--|-------------------------------|------------------------|
| Report No.   | NLES/25-26/11/ST/RE/746   | Report Issue Date    | 25/11/2025   |                               |                        |
| Name and Address of Customer   | M/S. EMCURE PHARMACEUTICALS LTD.,<br>Plot No. 12/2, F 2 Block, MIDC, Pimpri, Pune - 411 018 |                      |  |                               |                        |
| Discipline   | Chemical  | Sample Description   | Stack Material: MS   |                               |                        |
| Group  | Pollution & Environment.  |                      | Stack Height: 30.0 Mtr   |                               |                        |
| Sub Group  | Stack Emission  |                      | Stack Type: Round  |                               |                        |
| Date of Sampling   | 17/11/2025  | Sampling Location    | (S1) Boiler – 1 (1.5 Ton)                                      |                               |                        |
| Time of Sampling   | 11:00   | Sampling duration    | 30 Min   |                               |                        |
| Sampling done by   | M/s VSK Enviro Solution   | Sampling Procedure   | CPCB Guideline on methodologies for source emission monitoring |                               |                        |
| Start Date of Analysis   | 18/11/2025  | End Date of Analysis | 24/11/2025   |                               |                        |
| Results  |   |                      |  |                               |                        |
| Sr. No.  | Parameters  | Results              | Unit(s)  | Specifications (MPCB Consent) | Methods                |
| 1  | Flue Gas Temperature  | 457                  | °K   | -                             | -                      |
| 2  | Differential Pressure   | 5.4                  | mm WG  |                               |                        |
| 3  | Velocity  | 9.43                 | M/s  |                               |                        |
| 4  | Dimensions of Stack   | 0.73                 | Mtr.   |                               |                        |
| 5  | Stack Area  | 0.4183               | M <sup>2</sup>   |                               |                        |
| 6  | Gas Volume  | 9259.81              | Nm <sup>3</sup> /Hr  |                               |                        |
| 7  | Total Particulate Matter  | 42.63                | mg/Nm <sup>3</sup>   | ≤ 50                          | IS 11255 (Part 1)      |
| 8  | Carbon Monoxide   | 1.15                 | %  | N.S.                          | IS 13270:1992 RA 2014  |
| 9  | Carbon Dioxide  | 2.25                 | %  | N.S.                          | IS 11255 (Part 1)      |
| 10   | Hydrogen  | ND                   | PPM  | N.S.                          | IS 11255 (Part 4)      |
| 11   | Sulphur Dioxide (SO <sub>2</sub> )  | 28.40                | mg/Nm <sup>3</sup>   | N.S.                          | IS 11255 (Part 2)      |
| 12   | Sulphur Dioxide (SO <sub>2</sub> )  | 6.31                 | Kg/day   | ≤ 37.44                       | IS 11255 (Part 2)      |
| 13   | Oxides of Nitrogen (NO <sub>x</sub> )   | 1.1                  | mg/Nm <sup>3</sup>   | N.S.                          | IS11255 (PART 7): 2005 |
| Remark.  |   |                      |  |                               |                        |
| <ul style="list-style-type: none"> <li>All above results are well within MPCB Limit.</li> <li>N.S - Not Specified, BDL – Below Detection Limit &amp; ND – Not Detected.</li> </ul> |   |                      |  |                               |                        |

## Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

*Kalyani*  
 Reviewed By  
 (Ms. Kalyani Gore)



*Abhishek*  
 Authorized Signatory  
 (Mr. Abhishek Tope)

\*\*\*\*\*End of Report\*\*\*\*\*

Reviewed by  
*ABJ*  
 01.12.25

Page 1 of 1

# Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501  
 Website : www.neetalenvirolab.com, Mob. 8669699854 / 52  
 Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :  
 ISO 9001 : 2015  
 ISO 14001 : 2015  
 ISO 45001 : 2018

| TEST REPORT (Stack Emission)   |   |                      |  |                               |                        |
|--|---|----------------------|--|-------------------------------|------------------------|
| Report No.   | NLES/25-26/11/ST/RE/747   | Report Issue Date    | 25/11/2025   |                               |                        |
| Name and Address of Customer   | M/S. EMCURE PHARMACEUTICALS LTD.,<br>Plot No. 12/2, F 2 Block, MIDC, Pimpri, Pune - 411 018 |                      |  |                               |                        |
| Discipline   | Chemical  | Sample Description   | Stack Material: MS   |                               |                        |
| Group  | Pollution & Environment.  |                      | Stack Height: 30.0 Mtr   |                               |                        |
| Sub Group  | Stack Emission  |                      | Stack Type: Round  |                               |                        |
| Date of Sampling   | 17/11/2025  | Sampling Location    | (S1) Boiler - 2 (0.6 Ton)                                      |                               |                        |
| Time of Sampling   | 11:35   | Sampling duration    | 30 Min   |                               |                        |
| Sampling done by   | M/s VSK Enviro Solution   | Sampling Procedure   | CPCB Guideline on methodologies for source emission monitoring |                               |                        |
| Start Date of Analysis   | 18/11/2025  | End Date of Analysis | 24/11/2025   |                               |                        |
| Results  |   |                      |  |                               |                        |
| Sr. No.  | Parameters  | Results              | Unit(s)  | Specifications (MPCB Consent) | Methods                |
| 1  | Flue Gas Temperature  | 362                  | °K   | --                            | --                     |
| 2  | Differential Pressure   | 4.5                  | mm WG  |                               |                        |
| 3  | Velocity  | 7.66                 | M/s  |                               |                        |
| 4  | Dimensions of Stack   | 0.73                 | Mtr.   |                               |                        |
| 5  | Stack Area  | 0.4183               | M <sup>2</sup>   |                               |                        |
| 6  | Gas Volume  | 9495.69              | Nm <sup>3</sup> /Hr  |                               |                        |
| 7  | Total Particulate Matter  | 33.12                | mg/Nm <sup>3</sup>   | ≤ 50                          | IS 11255 (Part 1)      |
| 8  | Carbon Monoxide   | 0.61                 | %  | N.S.                          | IS 13270:1992 RA 2014  |
| 9  | Carbon Dioxide  | 2.37                 | %  | N.S.                          | IS 11255 (Part 1)      |
| 10   | Hydrogen  | ND                   | PPM  | N.S.                          | IS 11255 (Part 4)      |
| 11   | Sulphur Dioxide (SO <sub>2</sub> )  | 18.82                | mg/Nm <sup>3</sup>   | N.S.                          | IS 11255 (Part 2)      |
| 12   | Sulphur Dioxide (SO <sub>2</sub> )  | 4.29                 | Kg/day   | ≤ 15.55                       | IS 11255 (Part 2)      |
| 13   | Oxides of Nitrogen (NO <sub>x</sub> )   | 0.6                  | mg/Nm <sup>3</sup>   | N.S.                          | IS11255 (PART 7): 2005 |
| Remark.  |   |                      |  |                               |                        |
| <ul style="list-style-type: none"> <li>All above results are well within MPCB Limit.</li> <li>N.S - Not Specified, BDL – Below Detection Limit &amp; ND – Not Detected.</li> </ul> |   |                      |  |                               |                        |

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

*Kalyani*  
 Reviewed By  
 (Ms. Kalyani Gore)



*Abhishek*  
 Authorized Signatory  
 (Mr. Abhishek Tope)

\*\*\*\*\*End of Report\*\*\*\*\*

Reviewed by  
*ASD*  
 01.12.25

# Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501  
 Website : www.neetalenvirolab.com, Mob. 8669699854 / 52  
 Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :  
 ISO 9001 : 2015  
 ISO 14001 : 2015  
 ISO 45001 : 2018

| TEST REPORT (Stack Emission)  |   |                      |  |                               |                        |
|---|---|----------------------|--|-------------------------------|------------------------|
| Report No.  | NLES/25-26/11/ST/RE/748   | Report Issue Date    | 25/11/2025   |                               |                        |
| Name and Address of Customer  | M/S. EMCURE PHARMACEUTICALS LTD.,<br>Plot No. 12/2, F 2 Block, MIDC, Pimpri, Pune - 411 018 |                      |  |                               |                        |
| Discipline  | Chemical  | Sample Description   | Stack Material: MS   |                               |                        |
| Group   | Pollution & Environment.  |                      | Stack Height: 4.5 Mtr  |                               |                        |
| Sub Group   | Stack Emission  |                      | Stack Type: Round  |                               |                        |
| Date of Sampling  | 17/11/2025  | Sampling Location    | (S2) D. G. Set 1010 KVA (D.G-204)                              |                               |                        |
| Time of Sampling  | 12:10   | Sampling duration    | 30 Min   |                               |                        |
| Sampling done by  | M/s VSK Enviro Solution   | Sampling Procedure   | CPCB Guideline on methodologies for source emission monitoring |                               |                        |
| Start Date of Analysis  | 18/11/2025  | End Date of Analysis | 24/11/2025   |                               |                        |
| Results   |   |                      |  |                               |                        |
| Sr. No.   | Parameters  | Results              | Unit(s)  | Specifications (MPCB Consent) | Methods                |
| 1   | Flue Gas Temperature  | 571                  | °K   | --                            | --                     |
| 2   | Differential Pressure   | 6.1                  | mm WG  |                               |                        |
| 3   | Velocity  | 11.20                | M/s  |                               |                        |
| 4   | Dimensions of Stack   | 0.35                 | Mtr.   |                               |                        |
| 5   | Stack Area  | 0.0962               | M <sup>2</sup>   |                               |                        |
| 6   | Gas Volume  | 2024.30              | Nm <sup>3</sup> /Hr  |                               |                        |
| 7   | Total Particulate Matter  | 49.02                | mg/Nm <sup>3</sup>   | ≤ 50                          | IS 11255 (Part 1)      |
| 8   | Carbon Monoxide   | 0.849                | %  | N.S.                          | IS 13270:1992 RA 2014  |
| 9   | Carbon Dioxide  | 2.25                 | %  | N.S.                          | IS 11255 (Part 1)      |
| 10  | Hydrogen  | BDL                  | PPM  | N.S.                          | IS 11255 (Part 4)      |
| 11  | Sulphur Dioxide (SO <sub>2</sub> )  | 38.96                | mg/Nm <sup>3</sup>   | N.S.                          | IS 11255 (Part 2)      |
| 12  | Sulphur Dioxide (SO <sub>2</sub> )  | 1.89                 | Kg/day   | ≤ 3.52                        | IS 11255 (Part 2)      |
| 13  | Oxides of Nitrogen (NO <sub>x</sub> )   | 4.2                  | mg/Nm <sup>3</sup>   | N.S.                          | IS11255 (PART 7): 2005 |
| Remark.   |   |                      |  |                               |                        |
| <ul style="list-style-type: none"> <li>All above results are well within MPCB Limit.</li> <li>N.S - Not Specified &amp; BDL – Below Detection Limit.</li> </ul> |   |                      |  |                               |                        |

**Terms and Conditions**

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

*Kalyani*  
 Reviewed By  
 (Ms. Kalyani Gore)



*Abhishek*  
 Authorized Signatory  
 (Mr. Abhishek Tope)

\*\*\*\*\*End of Report\*\*\*\*\*

Reviewed by  
*AS*  
 01.12.25