

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

Annexure - VIII

TEST REPORT					
Report No:	NLES/25-26/03/WW/RE/1132	Issue Date	11/03/2026		
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802				
Discipline	Chemical	Date of Sample Collection	05/03/2026		
Sub Group	Waste Water	Sample Quantity	02 Liter Plastic can + 1000 ml Glass Bottle		
Sample Description	ETP Outlet	Sample Status	Sealed		
Sample collected by	M/s VSK Enviro Solution				
Start Date of Analysis	06/03/2026	End Date of Analysis	10/03/2026		
Results					
Sr. No.	Parameters	Results	Unit(s)	MPCB Limits	Methods
1	pH at 25°C	7.43	-	6.0-8.5	APHA 4500, H+, B: 24th Ed.2023
2	Total Suspended Solids (TSS)	32.0	mg/l	<100	APHA2540, D, 24th Ed. 2023
3	Total Dissolve Solids	713.0	mg/l	<2100	APHA-2540-D,24th Ed.2023
4	Chemical Oxygen Demand	76.5	mg/l	<250	IS 3025 (Part 58), 2006
5	Biochemical Oxygen Demand (BOD) 3 days at 27°C	21.0	mg/l	<30	IS 3025 (Part 44), 2019
6	Chloride (as Cl)	84.0	mg/l	<600	IS 3025 (Part 32), 2019
7	Sulphate (as SO4)	54.0	mg/l	<1000	APHA 4500 SO4, E, 24th Ed. 2023
8	Oil & Grease (O & G)	<5.0	mg/l	<10	IS 3025 (Part 39), Method (a), 2021
9	Phosphate	0.88	mg/l	<5.0	APHA 24th Ed,4500-P D
10	Phenol	<0.001	mg/l	<1	APHA 24th Ed 5530 D
11	Zinc	<0.01	mg/l	<5	APHA 24th Ed ,3111 B
12	Ammoniacal Nitrogen as NH ₃ -N	<0.07	mg/l	NS	APHA 24th Ed., 4500-NH ₃ C
13	Bioassay Test	91 % Survival of fish after 24 hours in 100 % effluent		NS	APHA 24th Ed., 10600
Remark-The above results are within MPCB Limits. NS – Not Specified. BDL- Below detection Limit.					

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

Verified By *[Signature]*
Date: *06.04.26*
Department EHS

*****End of Report*****

Page 1 of 1

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501
 Website : www.neetalenvirolab.com, Mob. 8669699854 / 52
 Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
 ISO 9001 : 2015
 ISO 14001 : 2015
 ISO 45001 : 2018

TEST REPORT

Report No:	NLES/25-26/02/WW/RE/806	Issue Date	13/02/2026		
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802				
Discipline	Chemical	Date of Sample Collection	05/02/2026		
Sub Group	Waste Water	Sample Quantity	02 Liter Plastic can + 1000 ml Glass Bottle		
Sample Description	ETP Outlet	Sample Status	Sealed		
Sample collected by	M/s VSK Enviro Solution				
Start Date of Analysis	06/02/2026	End Date of Analysis	12/02/2026		
Results					
Sr. No.	Parameters	Results	Unit(s)	MPCB Limits	Methods
1	pH at 25°C	7.68	-	6.0-8.5	APHA 4500, H+, B: 24th Ed.2017
2	Total Suspended Solids (TSS)	38.0	mg/l	<100	APHA2540, D, 24th Ed. 2017
3	Total Dissolve Solids	645.0	mg/l	<2100	APHA-2540-D,24th Ed.2017
4	Chemical Oxygen Demand	52.5	mg/l	<250	IS 3025 (Part 58), 2006
5	Biochemical Oxygen Demand (BOD) 3 days at 27°C	15.0	mg/l	<30	IS 3025 (Part 44), 2019
6	Chloride (as Cl)	78.0	mg/l	<600	IS 3025 (Part 44), 2019
7	Sulphate (as SO4)	49.0	mg/l	<1000	APHA 4500 SO4, E, 24th Ed. 2017
8	Oil & Grease (O & G)	<5.0	mg/l	<10	IS 3025 (Part 39), Method (a), 2021
9	Phosphate	0.84	mg/l	<5.0	APHA 24th Ed,4500-P D
10	Phenol	<0.001	mg/l	<1	APHA 24th Ed 5530 D
11	Zinc	<0.01	mg/l	<5	APHA 24th Ed ,3111 B
12	Ammoniacal Nitrogen as NH ₃ -N	<0.07	mg/l	NS	APHA 24th Ed., 4500-NH ₃ °C
13	Bioassay Test	93 % Survival of fish after 24 hours in 100 % effluent		NS	APHA 24th Ed., 10600
Remark-The above results are within MPCB Limits. NS – Not Specified. BDL- Below detection Limit.					

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
 Reviewed By
 (Ms. Kalyani Gore)



Abhishek
 Authorized Signatory
 (Mr. Abhishek Tope)

Verified By

Date:

Department EHS

Kalyani
 05-03-26

*****End of Report*****

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501
Website : www.neetalenvirolab.com, Mob. 8669699854 / 52
Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT

Report No:	NLES/25-26/01/WW/RE/909	Issue Date	13/01/2026
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Date of Sample Collection	06/01/2026
Sub Group	Waste Water	Sample Quantity	02 Liter Plastic can + 01 Liter Glass Bottle
Sample Description	ETP Outlet	Sample Status	Sealed
Sample collected by	M/s VSK Enviro Solution		
Start Date of Analysis	07/01/2026	End Date of Analysis	12/01/2026

Results

Sr. No.	Parameters	Results	Unit(s)	MPCB Limits	Methods
1	pH at 25°C	7.36	-	6.0-8.5	APHA 4500, H+, B: 24th Ed.2023
2	Total Suspended Solids (TSS)	46.0	mg/l	<100	APHA2540, D, 24th Ed. 2023
3	Total Dissolve Solids	772.0	mg/l	<2100	APHA-2540-D,24th Ed.2023
4	Chemical Oxygen Demand	68.4	mg/l	<250	IS 3025 (Part 58), 2006
5	Biochemical Oxygen Demand (BOD) 3 days at 27°C	19.0	mg/l	<30	IS 3025 (Part 44), 2019
6	Chloride (as Cl)	84.0	mg/l	<600	IS 3025 (Part 44), 2019
7	Sulphate (as SO4)	54.0	mg/l	<1000	APHA 4500 SO4, E, 24th Ed. 2023
8	Oil & Grease (O & G)	BDL	mg/l	<10	IS 3025 (Part 39), Method (a), 2021
9	Phosphate	0.92	mg/l	<5.0	APHA 24th Ed,4500-P D
10	Phenol	<0.001	mg/l	<1	APHA 24th Ed 5530 D
11	Zinc	<0.01	mg/l	<5	APHA 24th Ed ,3111 B
12	Ammoniacal Nitrogen as NH ₃ -N	<0.07	mg/l	NS	APHA 24th Ed., 4500-NH ₃ C
13	Bioassay Test	91 % Survival of fish after 24 hours in 100 % effluent		NS	APHA 24th Ed., 10600

Remark-The above results are within MPCB Limits.

NS – Not Specified. BDL- Below detection Limit.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Sarika

Reviewed By
(Ms. Sarika Pansare)



Kalyani
Authorized Signatory
(Ms. Kalyani Gore)

Verified By

Date:

Department EHS

Abheer
06.02.26

*****End of Report*****

Page 1 of 1

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :

ISO 9001 : 2015

ISO 14001 : 2015

ISO 45001 : 2018

TEST REPORT

Report No:	NLES/25-26/12/WW/RE/1296	Issue Date	10/12/2025		
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802				
Discipline	Chemical	Date of Sample Collection	03/12/2025		
Sub Group	Waste Water	Sample Quantity	02 Liter Plastic can + 01 Liter Glass Bottle		
Sample Description	ETP Outlet	Sample Status	Sealed		
Sample collected by	M/s VSK Enviro Solution				
Start Date of Analysis	04/12/2025	End Date of Analysis	09/12/2025		
Results					
Sr. No.	Parameters	Results	Unit(s)	MPCB Limits	Methods
1	pH at 25°C	7.43	-	6.0-8.5	APHA 4500, H+, B: 24th Ed.2023
2	Total Suspended Solids (TSS)	32.0	mg/l	<100	APHA2540, D, 24th Ed. 2023
3	Total Dissolve Solids	713.0	mg/l	<2100	APHA-2540-D,24th Ed.2023
4	Chemical Oxygen Demand	67.6	mg/l	<250	IS 3025 (Part 58), 2006
5	Biochemical Oxygen Demand (BOD) 3 days at 27°C	22.0	mg/l	<30	IS 3025 (Part 44), 2019
6	Chloride (as Cl)	95.0	mg/l	<600	IS 3025 (Part 44), 2019
7	Sulphate (as SO4)	67.0	mg/l	<1000	APHA 4500 SO4, E, 24th Ed. 2023
8	Oil & Grease (O & G)	BDL	mg/l	<10	IS 3025 (Part 39), Method (a), 2021
9	Phosphate	0.96	mg/l	<5.0	APHA 24th Ed,4500-P D
10	Phenol	<0.001	mg/l	<1	APHA 24th Ed 5530 D
11	Zinc	<0.01	mg/l	<5	APHA 24th Ed ,3111 B
12	Ammoniacal Nitrogen as NH ₃ -N	<0.07	mg/l	NS	APHA 24th Ed., 4500-NH ₃ C
13	Bioassay Test	94 % Survival of fish after 24 hours in 100 % effluent		NS	APHA 24th Ed., 10600
Remark-The above results are within MPCB Limits. NS – Not Specified. BDL- Below detection Limit.					

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Verified By *Arjun*
Date: *06-01-26*
Department EHS

Page 1 of 1

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT

Report No:	NLES/25-26/11/WW/RE/662	Issue Date	13/11/2025		
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802				
Discipline	Chemical	Date of Sample Collection	05/11/2025		
Sub Group	Waste Water	Sample Quantity	02 Liter Plastic can + 1 Liter Glass Bottle		
Sample Description	ETP Outlet	Sample Status	Sealed		
Sample collected by	M/s VSK Enviro Solution				
Start Date of Analysis	06/11/2025	End Date of Analysis	12/11/2025		
Results					
Sr. No.	Parameters	Results	Unit(s)	MPCB Limits	Methods
1	pH at 25°C	7.22	-	6.0-8.5	APHA 4500, H+, B: 24th Ed.2023
2	Total Suspended Solids (TSS)	37.0	mg/l	<100	APHA2540, D, 24th Ed. 2023
3	Total Dissolve Solids	749.0	mg/l	<2100	APHA-2540-D,24th Ed.2023
4	Chemical Oxygen Demand	72.0	mg/l	<250	IS 3025 (Part 58), 2006
5	Biochemical Oxygen Demand (BOD) 3 days at 27°C	20.0	mg/l	<30	IS 3025 (Part 44), 2019
6	Chloride (as Cl)	91.0	mg/l	<600	APHA 24 th Edition4500-Cl B:2023
7	Sulphate (as SO4)	62.0	mg/l	<1000	APHA 4500 SO4, E, 24th Ed. 2023
8	Oil & Grease (O & G)	BDL	mg/l	<10	IS 3025 (Part 39), Method (a), 2021
9	Phosphate	0.92	mg/l	<5.0	APHA 24 th Ed,4500-P D
10	Phenol	<0.001	mg/l	<1	APHA 24 th Ed 5530 D
11	Zinc	<0.01	mg/l	<5	APHA 24 th Ed ,3111 B
12	Ammoniacal Nitrogen as NH ₃ -N	<0.07	mg/l	NS	APHA 24 th Ed., 4500-NH ₃ C
13	Bioassay Test	92 % Survival of fish after 24 hours in 100 % effluent		NS	APHA 24 th Ed., 10600
Remark-The above results are within MPCB Limits. NS – Not Specified. BDL- Below detection Limit.					

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Verified By *Heer*
Date: *04.12.25*
Department EHS

Page 1 of 1

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT

Report No:	NLES/25-26/10/WW/RE/616	Issue Date	11/10/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Date of Sample Collection	03/10/2025
Sub Group	Waste Water	Sample Quantity	02 Liter Plastic can + 1000 ml Glass Bottle
Sample Description	ETP Outlet	Sample Status	Sealed
Sample collected by	M/s VSK Enviro Solution		
Start Date of Analysis	04/10/2025	End Date of Analysis	10/10/2025

Results

Sr. No.	Parameters	Results	Unit(s)	MPCB Limits	Methods
1	pH at 25°C	7.48	-	6.0-8.5	APHA 4500, H+, B: 24th Ed.2023
2	Total Suspended Solids (TSS)	43.0	mg/l	<100	APHA2540, D, 24th Ed. 2023
3	Total Dissolve Solids	761.0	mg/l	<2100	APHA-2540-D,24th Ed.2023
4	Chemical Oxygen Demand	64.8	mg/l	<250	IS 3025 (Part 58), 2006
5	Biochemical Oxygen Demand (BOD) 3 days at 27°C	18.0	mg/l	<30	IS 3025 (Part 44), 2019
6	Chloride (as Cl)	86.0	mg/l	<600	IS 3025 (Part 44), 2019
7	Sulphate (as SO4)	51.0	mg/l	<1000	APHA 4500 SO4, E, 24th Ed. 2023
8	Oil & Grease (O & G)	BDL	mg/l	<10	IS 3025 (Part 39), Method (a), 2021
9	Phosphate	0.89	mg/l	<5.0	APHA 24th Ed,4500-P D
10	Phenol	<0.001	mg/l	<1	APHA 24th Ed 5530 D
11	Zinc	<0.01	mg/l	<5	APHA 24th Ed ,3111 B
12	Ammoniacal Nitrogen as NH ₃ -N	<0.07	mg/l	NS	APHA 24th Ed., 4500-NH ₃ °C
13	Bioassay Test	95 % Survival of fish after 24 hours in 100 % effluent		NS	APHA 24th Ed., 10600

Remark-The above results are within MPCB Limits.

NS – Not Specified. BDL- Below detection Limit.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Verified By

Date:

Department EHS

Page 1 of 1

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :

ISO 9001 : 2015

ISO 14001 : 2015

ISO 45001 : 2018

TEST REPORT

Report No:	NLES/25-26/03/WW/RE/1130	Issue Date	11/03/2026
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Date of Sample Collection	05/03/2026
Sub Group	Waste Water	Sample Quantity	02 Liter Plastic can + 1000 ml Glass Bottle
Sample Description	STP Outlet	Sample Status	Sealed
Sample collected by	M/s VSK Enviro Solution		
Start Date of Analysis	06/03/2026	End Date of Analysis	10/03/2026

Results

Sr. No.	Parameters	Results	Unit(s)	MPCB Limits	Methods
1	pH at 25°C	7.48	-	5.5-8.5	APHA 4500, H+, B: 24th Ed.2023
2	Total Suspended Solids (TSS)	17.0	mg/l	<50	APHA2540, D, 24th Ed. 2023
3	Chemical Oxygen Demand	39.0	mg/l	<100	IS 3025 (Part 58), 2006
4	Biochemical Oxygen Demand (BOD) 3 days at 27°C	9.0	mg/l	<30	IS 3025 (Part 44), 2019
5	Oil & Grease (O & G)	<5.0	mg/l	NS	IS 3025 (Part 39), Method (a), 2021
6	Total Dissolve Solids	354.0	mg/l	NS	APHA-2540-C, 24th Ed.2023

Remark-The above results are within MPCB Limits.

NS – Not Specified. BDL- Below detection Limit.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Page 1 of 1

Verified By
Date: *08.04.26*
Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501
Website : www.neetalenvirolab.com, Mob. 8669699854 / 52
Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT

Report No:	NLES/25-26/02/WW/RE/804	Issue Date	13/02/2026		
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802				
Discipline	Chemical	Date of Sample Collection	05/02/2026		
Sub Group	Waste Water	Sample Quantity	02 Liter Plastic can + 1000 ml Glass Bottle		
Sample Description	STP Outlet	Sample Status	Sealed		
Sample collected by	M/s VSK Enviro Solution				
Start Date of Analysis	06/02/2026	End Date of Analysis	12/02/2026		
Results					
Sr. No.	Parameters	Results	Unit(s)	MPCB Limits	Methods
1	pH at 25°C	7.34	-	5.5-8.5	APHA 4500, H+, B: 24th Ed.2017
2	Total Suspended Solids (TSS)	13.0	mg/l	<50	APHA2540, D, 24th Ed. 2017
3	Chemical Oxygen Demand	27.2	mg/l	<100	IS 3025 (Part 58), 2006
4	Biochemical Oxygen Demand (BOD) 3 days at 27°C	8.0	mg/l	<30	IS 3025 (Part 44), 2019
5	Oil & Grease (O & G)	<5.0	mg/l	NS	IS 3025 (Part 39), Method (a), 2021
6	Total Dissolve Solids	316.0	mg/l	NS	APHA-2540-C, 24th Ed.2017
Remark-The above results are within MPCB Limits. NS – Not Specified. BDL- Below detection Limit.					

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Page 1 of 1

Verified By *Heena*
Date: *05.03.26*
Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT

Report No:	NLES/25-26/01/WW/RE/907	Issue Date	13/01/2026		
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802				
Discipline	Chemical	Date of Sample Collection	06/01/2026		
Sub Group	Waste Water	Sample Quantity	02 Liter Plastic can + 01 Liter Glass Bottle		
Sample Description	STP Outlet	Sample Status	Sealed		
Sample collected by	M/s VSK Enviro Solution				
Start Date of Analysis	07/01/2026	End Date of Analysis	12/01/2026		
Results					
Sr. No.	Parameters	Results	Unit(s)	MPCB Limits	Methods
1	pH at 25°C	7.52	-	5.5-8.5	APHA 4500, H+, B: 24th Ed.2023
2	Total Suspended Solids (TSS)	18.0	mg/l	<50	APHA2540, D, 24th Ed. 2023
3	Chemical Oxygen Demand	40.7	mg/l	<100	IS 3025 (Part 58), 2006
4	Biochemical Oxygen Demand (BOD) 3 days at 27°C	11.0	mg/l	<30	IS 3025 (Part 44), 2019
5	Oil & Grease (O & G)	BDL	mg/l	NS	IS 3025 (Part 39), Method (a), 2021
6	Total Dissolve Solids	368.0	mg/l	NS	APHA-2540-C, 24th Ed.2023
Remark-The above results are within MPCB Limits. NS – Not Specified. BDL- Below detection Limit.					

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Sarika
Reviewed By
(Ms. Sarika Pansare)



Kalyani
Authorized Signatory
(Ms. Kalyani Gore)

*****End of Report*****

Page 1 of 1

Verified By
Date: 06.02.26
Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT

Report No:	NLES/25-26/12/WW/RE/1294	Issue Date	10/12/2025		
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802				
Discipline	Chemical	Date of Sample Collection	03/12/2025		
Sub Group	Waste Water	Sample Quantity	02 Liter Plastic can + 01 Liter Glass Bottle		
Sample Description	STP Outlet	Sample Status	Sealed		
Sample collected by	M/s VSK Enviro Solution				
Start Date of Analysis	04/12/2025	End Date of Analysis	09/12/2025		
Results					
Sr. No.	Parameters	Results	Unit(s)	MPCB Limits	Methods
1	pH at 25°C	7.26	-	5.5-8.5	APHA 4500, H+, B: 24th Ed.2023
2	Total Suspended Solids (TSS)	11.0	mg/l	<50	APHA2540, D, 24th Ed. 2023
3	Chemical Oxygen Demand	42.1	mg/l	<100	IS 3025 (Part 58), 2006
4	Biochemical Oxygen Demand (BOD) 3 days at 27°C	14.0	mg/l	<30	IS 3025 (Part 44), 2019
5	Oil & Grease (O & G)	BDL	mg/l	NS	IS 3025 (Part 39), Method (a), 2021
6	Total Dissolve Solids	395.0	mg/l	NS	APHA-2540-C, 24th Ed.2023
Remark-The above results are within MPCB Limits. NS – Not Specified. BDL - Below detection Limit.					

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Page 1 of 1

Verified By
Date: *06-01-20*
Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT

Report No:	NLES/25-26/11/WW/RE/660	Issue Date	13/11/2025		
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802				
Discipline	Chemical	Date of Sample Collection	05/11/2025		
Sub Group	Waste Water	Sample Quantity	02 Liter Plastic can + 1 Liter Glass Bottle		
Sample Description	STP Outlet	Sample Status	Sealed		
Sample collected by	M/s VSK Enviro Solution				
Start Date of Analysis	06/11/2025	End Date of Analysis	12/11/2025		
Results					
Sr. No.	Parameters	Results	Unit(s)	MPCB Limits	Methods
1	pH at 25°C	7.39	-	5.5-8.5	APHA 4500, H+, B: 24th Ed.2023
2	Total Suspended Solids (TSS)	10.0	mg/l	<50	APHA2540, D, 24th Ed. 2023
3	Chemical Oxygen Demand	44.4	mg/l	<100	IS 3025 (Part 58), 2006
4	Biochemical Oxygen Demand (BOD) 3 days at 27°C	12.0	mg/l	<30	IS 3025 (Part 44), 2019
5	Oil & Grease (O & G)	BDL	mg/l	NS	IS 3025 (Part 39), Method (a), 2021
6	Total Dissolve Solids	405.0	mg/l	NS	APHA-2540-C, 24th Ed.2023
Remark-The above results are within MPCB Limits. NS – Not Specified. BDL - Below detection Limit.					

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Verified By *Neeraj*
Date: *04.12.25*
Department EHS

Page 1 of 1

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT

Report No:	NLES/25-26/10/WW/RE/614	Issue Date	11/10/2025		
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802				
Discipline	Chemical	Date of Sample Collection	03/10/2025		
Sub Group	Waste Water	Sample Quantity	02 Liter Plastic can + 1000 ml Glass Bottle		
Sample Description	STP Outlet	Sample Status	Sealed		
Sample collected by	M/s VSK Enviro Solution				
Start Date of Analysis	04/10/2025	End Date of Analysis	10/10/2025		
Results					
Sr. No.	Parameters	Results	Unit(s)	MPCB Limits	Methods
1	pH at 25°C	7.64	-	5.5-8.5	APHA 4500, H+, B: 24th Ed.2023
2	Total Suspended Solids (TSS)	12.0	mg/l	<50	APHA2540, D, 24th Ed. 2023
3	Chemical Oxygen Demand	33.3	mg/l	<100	IS 3025 (Part 58), 2006
4	Biochemical Oxygen Demand (BOD) 3 days at 27°C	9.0	mg/l	<30	IS 3025 (Part 44), 2019
5	Oil & Grease (O & G)	BDL	mg/l	NS	IS 3025 (Part 39), Method (a), 2021
6	Total Dissolve Solids	416.0	mg/l	NS	APHA-2540-C, 24th Ed.2023
Remark-The above results are within MPCB Limits. NS – Not Specified. BDL- Below detection Limit.					

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Page 1 of 1

Verified By *Heena*
Date: *07-11-25*
Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT

Report No:	NLES/25-26/03/WW/RE/1133	Issue Date	11/03/2026
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Date of Sample Collection	05/03/2026
Sub Group	Waste Water	Sample Quantity	02 Liter Plastic can + 1000 ml Glass Bottle
Sample Description	RO Permit	Sample Status	Sealed
Sample collected by	M/s VSK Enviro Solution		
Start Date of Analysis	06/03/2026	End Date of Analysis	10/03/2026

Results

Sr. No.	Parameters	Results	Unit(s)	MPCB Limits	Methods
1	pH at 25°C	7.53	-	6.0-8.5	APHA 4500, H+, B: 24th Ed.2023
2	Total Suspended Solids (TSS)	<5.0	mg/l	<100	APHA2540, D, 24th Ed. 2023
3	Total Dissolve Solids	72.0	mg/l	<2100	APHA-2540-D,24th Ed.2023
4	Chemical Oxygen Demand	<4.0	mg/l	<250	IS 3025 (Part 58), 2006
5	Biochemical Oxygen Demand (BOD) 3 days at 27°C	<2.0	mg/l	<30	IS 3025 (Part 44), 2019
6	Chloride (as Cl)	56.0	mg/l	<600	IS 3025 (Part 32), 2019
7	Sulphate (as SO4)	9.13	mg/l	<1000	APHA 4500 SO4, E, 24th Ed. 2023
8	Oil & Grease (O & G)	<5.0	mg/l	<10	IS 3025 (Part 39), Method (a), 2021
9	Phosphate	0.62	mg/l	<5	APHA 4500 P-D, 24th Ed.2023
10	Phenol	<0.001	mg/l	<1	APHA 24th Ed 5530 D
11	Zinc	<0.01	mg/l	<5	APHA 24th Ed ,3111 B
12	Ammoniacal Nitrogen as NH ₃ -N	<0.07	mg/l	NS	APHA 24th Ed., 4500-NH ₃ C

Remark-The above results are within MPCB Limits.

NS – Not Specified. BDL- Below detection Limit.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Page 1 of 1

Verified By *Abhishek*
Date: 06.04.26
Department EHS

TEST REPORT

Report No:	NLES/25-26/02/WW/RE/807	Issue Date	13/02/2026
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Date of Sample Collection	05/02/2026
Sub Group	Waste Water	Sample Quantity	02 Liter Plastic can + 1000 ml Glass Bottle
Sample Description	RO Permit	Sample Status	Sealed
Sample collected by	M/s VSK Enviro Solution		
Start Date of Analysis	06/02/2026	End Date of Analysis	12/02/2026

Results

Sr. No.	Parameters	Results	Unit(s)	MPCB Limits	Methods
1	pH at 25°C	7.34	-	6.0-8.5	APHA 4500, H+, B: 24th Ed.2017
2	Total Suspended Solids (TSS)	<5.0	mg/l	<100	APHA2540, D, 24th Ed. 2017
3	Total Dissolve Solids	69.0	mg/l	<2100	APHA-2540-D,24th Ed.2017
4	Chemical Oxygen Demand	<4.0	mg/l	<250	IS 3025 (Part 58), 2006
5	Biochemical Oxygen Demand (BOD) 3 days at 27°C	<2.0	mg/l	<30	IS 3025 (Part 44), 2019
6	Chloride (as Cl)	49.0	mg/l	<600	IS 3025 (Part 44), 2019
7	Sulphate (as SO4)	8.20	mg/l	<1000	APHA 4500 SO4, E, 24th Ed. 2017
8	Oil & Grease (O & G)	BDL	mg/l	<10	IS 3025 (Part 39), Method (a), 2021
9	Phosphate	0.41	mg/l	<5	APHA 4500 P-D, 24th Ed.2017
10	Phenol	<0.001	mg/l	<1	APHA 24th Ed 5530 D
11	Zinc	<0.01	mg/l	<5	APHA 24th Ed ,3111 B
12	Ammoniacal Nitrogen as NH ₃ -N	<0.07	mg/l	NS	APHA 24th Ed., 4500-NH ₃ C

Remark-The above results are within MPCB Limits.

NS – Not Specified. BDL- Below detection Limit.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

Verified By
Date: *05.03.26*
Department EHS

*****End of Report*****

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501
Website : www.neetalenvirolab.com, Mob. 8669699854 / 52
Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT

Report No:	NLES/25-26/01/WW/RE/910	Issue Date	13/01/2026		
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802				
Discipline	Chemical	Date of Sample Collection	06/01/2026		
Sub Group	Waste Water	Sample Quantity	02 Liter Plastic can + 01 Liter Glass Bottle		
Sample Description	RO Permit	Sample Status	Sealed		
Sample collected by	M/s VSK Enviro Solution				
Start Date of Analysis	07/01/2026	End Date of Analysis	12/01/2026		
Results					
Sr. No.	Parameters	Results	Unit(s)	MPCB Limits	Methods
1	pH at 25°C	7.46	-	6.0-8.5	APHA 4500, H+, B: 24th Ed.2023
2	Total Suspended Solids (TSS)	<5.0	mg/l	<100	APHA2540, D, 24th Ed. 2023
3	Total Dissolve Solids	72.0	mg/l	<2100	APHA-2540-D,24th Ed.2023
4	Chemical Oxygen Demand	<4.0	mg/l	<250	IS 3025 (Part 58), 2006
5	Biochemical Oxygen Demand (BOD) 3 days at 27°C	<2.0	mg/l	<30	IS 3025 (Part 44), 2019
6	Chloride (as Cl)	54.0	mg/l	<600	IS 3025 (Part 44), 2019
7	Sulphate (as SO4)	9.04	mg/l	<1000	APHA 4500 SO4, E, 24th Ed. 2023
8	Oil & Grease (O & G)	BDL	mg/l	<10	IS 3025 (Part 39), Method (a), 2021
9	Phosphate	0.52	mg/l	<5	APHA 4500 P-D, 24th Ed.2023
10	Phenol	<0.001	mg/l	<1	APHA 24th Ed 5530 D
11	Zinc	<0.01	mg/l	<5	APHA 24th Ed ,3111 B
12	Ammoniacal Nitrogen as NH ₃ -N	<0.07	mg/l	NS	APHA 24th Ed., 4500-NH ₃ C
Remark-The above results are within MPCB Limits. NS – Not Specified. BDL- Below detection Limit.					

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Sarika
Reviewed By
(Ms. Sarika Pansare)



Kalyani
Authorized Signatory
(Ms. Kalyani Gore)

*****End of Report*****

Verified By
Date: *06-02-26*
Department EHS

Page 1 of 1

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :

ISO 9001 : 2015

ISO 14001 : 2015

ISO 45001 : 2018

TEST REPORT

Report No:	NLES/25-26/12/WW/RE/1297	Issue Date	10/12/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Date of Sample Collection	03/12/2025
Sub Group	Waste Water	Sample Quantity	02 Liter Plastic can + 01 Liter Glass Bottle
Sample Description	RO Permit	Sample Status	Sealed
Sample collected by	M/s VSK Enviro Solution		
Start Date of Analysis	04/12/2025	End Date of Analysis	09/12/2025

Results

Sr. No.	Parameters	Results	Unit(s)	MPCB Limits	Methods
1	pH at 25°C	7.12	-	6.0-8.5	APHA 4500, H+, B: 24th Ed.2023
2	Total Suspended Solids (TSS)	<5.0	mg/l	<100	APHA2540, D, 24th Ed. 2023
3	Total Dissolve Solids	81.0	mg/l	<2100	APHA-2540-D,24th Ed.2023
4	Chemical Oxygen Demand	<4.0	mg/l	<250	IS 3025 (Part 58), 2006
5	Biochemical Oxygen Demand (BOD) 3 days at 27°C	<2.0	mg/l	<30	IS 3025 (Part 44), 2019
6	Chloride (as Cl)	68.0	mg/l	<600	IS 3025 (Part 44), 2019
7	Sulphate (as SO4)	8.98	mg/l	<1000	APHA 4500 SO4, E, 24th Ed. 2023
8	Oil & Grease (O & G)	<5.0	mg/l	<10	IS 3025 (Part 39), Method (a), 2021
9	Phosphate	0.69	mg/l	<5	APHA 4500 P-D, 24th Ed.2023
10	Phenol	<0.001	mg/l	<1	APHA 24th Ed 5530 D
11	Zinc	<0.01	mg/l	<5	APHA 24th Ed ,3111 B
12	Ammoniacal Nitrogen as NH ₃ -N	<0.07	mg/l	NS	APHA 24th Ed., 4500-NH ₃ C

Remark-The above results are within MPCB Limits.

NS – Not Specified. **BDL** Below detection Limit.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Page 1 of 1

Verified By
Date: *06-01-26*
Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501
Website : www.neetalenvirolab.com, Mob. 8669699854 / 52
Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT

Report No:	NLES/25-26/11/WW/RE/663	Issue Date	13/11/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Date of Sample Collection	05/11/2025
Sub Group	Waste Water	Sample Quantity	02 Liter Plastic can + 1 Liter Glass Bottle
Sample Description	RO Permit	Sample Status	Sealed
Sample collected by	M/s VSK Enviro Solution		
Start Date of Analysis	06/11/2025	End Date of Analysis	12/11/2025

Results

Sr. No.	Parameters	Results	Unit(s)	MPCB Limits	Methods
1	pH at 25°C	7.42	-	6.0-8.5	APHA 4500, H+, B: 24th Ed.2023
2	Total Suspended Solids (TSS)	<5.0	mg/l	<100	APHA2540, D, 24th Ed. 2023
3	Total Dissolve Solids	89.0	mg/l	<2100	APHA-2540-D,24th Ed.2023
4	Chemical Oxygen Demand	<4.0	mg/l	<250	IS 3025 (Part 58), 2006
5	Biochemical Oxygen Demand (BOD) 3 days at 27°C	<2.0	mg/l	<30	IS 3025 (Part 44), 2019
6	Chloride (as Cl)	79.0	mg/l	<600	APHA 24 th Edition4500-Cl B:2023
7	Sulphate (as SO ₄)	9.12	mg/l	<1000	APHA 4500 SO ₄ , E, 24th Ed. 2023
8	Oil & Grease (O & G)	BDL	mg/l	<10	IS 3025 (Part 39), Method (a), 2021
9	Phosphate	0.58	mg/l	<5	APHA 4500 P-D, 24th Ed.2023
10	Phenol	<0.001	mg/l	<1	APHA 24 th Ed 5530 D
11	Zinc	<0.01	mg/l	<5	APHA 24 th Ed ,3111 B
12	Ammoniacal Nitrogen as NH ₃ -N	<0.07	mg/l	NS	APHA 24 th Ed., 4500-NH ₃ C

Remark-The above results are within MPCB Limits.

NS – Not Specified. **BDL**- Below detection Limit.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Page 1 of 1

Verified By *Heena*
Date: *04.12.25*
Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT


Report No:	NLES/25-26/10/WW/RE/617	Issue Date	11/10/2025		
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802				
Discipline	Chemical	Date of Sample Collection	03/10/2025		
Sub Group	Waste Water	Sample Quantity	02 Liter Plastic can + 1000 ml Glass Bottle		
Sample Description	RO Permit	Sample Status	Sealed		
Sample collected by	M/s VSK Enviro Solution				
Start Date of Analysis	04/10/2025	End Date of Analysis	10/10/2025		
Results					
Sr. No.	Parameters	Results	Unit(s)	MPCB Limits	Methods
1	pH at 25°C	7.57	-	6.0-8.5	APHA 4500, H+, B: 24th Ed.2023
2	Total Suspended Solids (TSS)	<5.0	mg/l	<100	APHA2540, D, 24th Ed. 2023
3	Total Dissolve Solids	78.0	mg/l	<2100	APHA-2540-D,24th Ed.2023
4	Chemical Oxygen Demand	<4.0	mg/l	<250	IS 3025 (Part 58), 2006
5	Biochemical Oxygen Demand (BOD) 3 days at 27°C	<2.0	mg/l	<30	IS 3025 (Part 44), 2019
6	Chloride (as Cl)	57.0	mg/l	<600	IS 3025 (Part 44), 2019
7	Sulphate (as SO4)	8.91	mg/l	<1000	APHA 4500 SO4, E, 24th Ed. 2023
8	Oil & Grease (O & G)	BDL	mg/l	<10	IS 3025 (Part 39), Method (a), 2021
9	Phosphate	0.67	mg/l	<5	APHA 4500 P-D, 24th Ed.2023
10	Phenol	<0.001	mg/l	<1	APHA 24th Ed 5530 D
11	Zinc	<0.01	mg/l	<5	APHA 24th Ed ,3111 B
12	Ammoniacal Nitrogen as NH ₃ -N	<0.07	mg/l	NS	APHA 24th Ed., 4500-NH ₃ C
Remark-The above results are within MPCB Limits. NS – Not Specified. BDL- Below detection Limit.					

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.


Reviewed By
(Ms. Kalyani Gore)




Authorized Signatory
(Mr. Abhishek Tope)

Verified By
Date: 
07-11-25
Department EHS

*****End of Report*****

Page 1 of 1

TEST REPORT (Ambient Air)

Report No.	NLES/25-26/10/AA/RE/537	Report Issue Date	17/10/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Date & Time of Sampling	09/10/2025 Time: 10:45
Group	Atmospheric Pollution	Date of receipt of sample in lab	11/10/2025
Sub Group	Ambient Air	Sampling Procedure	IS 5182 Part 5
Sampling Location	Near Main Gate	Dry bulb temperature	31 °C
Wet bulb temperature	27 °C	Relative Humidity	73 %
Sampling done by	M/s VSK Enviro Solution		
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025
Name of Instrument	Ambient Air Combo Sampler 75	Date of Calibration	16/03/2025
Calibration Certificate No.	SSEC/FF/735	Due Date of Calibration	15/03/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (NAAQ Standards)	Methods
1	Sulphur Dioxide (SO ₂)	19.9	µg/m ³	≤ 80	IS 5182 (Part 2)
2	Oxides of Nitrogen (NO ₂)	24.1	µg/m ³	≤ 80	IS 5182 (Part 6)
3	Particulate Matter PM ₁₀	52.4	µg/m ³	≤ 100	IS 5182 (Part 4), 1999
4	Particulate Matter PM _{2.5}	19.1	µg/m ³	≤ 60	IS 5182 (Part 24), 2019
5	Ozone (O ₃)	19.64	µg/m ³	≤ 180	Method 411, Air Sampling and Analysis, 3rd Edition, 2020
6	Ammonia (NH ₃)	BDL	µg/m ³	≤ 400	Method 401, Air Sampling and Analysis 3rd Edition, 2020
7	Lead (Pb)	BDL	µg/m ³	≤ 01	Air Sampling and Analysis, 3rd Edition, 2020
8	Arsenic (As)	BDL	ng/m ³	≤ 06	
9	Nickel (Ni)	BDL	ng/m ³	≤ 20	
10	Carbon Monoxide (CO)	0.42	mg/m ³	≤ 04	GC FID Methanizer Method
11	Benzo(a)Pyrene (BaP)	BDL	ng/m ³	≤ 1.0	IS 5182 Part 12
12	Benzene(C ₆ H ₆)	BDL	µg/m ³	≤ 05	IS 5182 Part 11

Remark- All above results are within National Ambient Air Quality standards.

BDL – Bellow Detection Limit.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
 Reviewed By
 (Ms. Kalyani Gore)



Abhishek
 Authorized Signatory
 (Mr. Abhishek Tope)

***** End of Report *****

Verified By *[Signature]*
 Date: *01.11.25*
 Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Ambient Air)

Report No.	NLES/25-26/10/AA/RE/538	Report Issue Date	17/10/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Date & Time of Sampling	09/10/2025 Time: 10:40
Group	Atmospheric Pollution	Date of receipt of sample in lab	11/10/2025
Sub Group	Ambient Air	Sampling Procedure	IS 5182 Part 5
Sampling Location	Near ETP Office Front Side	Dry bulb temperature	31 °C
Wet bulb temperature	27 °C	Relative Humidity	73 %
Sampling done by	M/s VSK Enviro Solution		
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025
Name of Instrument	Ambient Air Combo Sampler 76	Date of Calibration	16/03/2025
Calibration Certificate No.	SSEC/FF/736	Due Date of Calibration	15/03/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (NAAQ Standards)	Methods
1	Sulphur Dioxide (SO ₂)	18.6	µg/m ³	≤ 80	IS 5182 (Part 2)
2	Oxides of Nitrogen (NO ₂)	23.1	µg/m ³	≤ 80	IS 5182 (Part 6)
3	Particulate Matter PM ₁₀	49.8	µg/m ³	≤ 100	IS 5182 (Part 4), 1999
4	Particulate Matter PM _{2.5}	17.2	µg/m ³	≤ 60	IS 5182 (Part 24), 2019
5	Ozone (O ₃)	19.71	µg/m ³	≤ 180	Method 411, Air Sampling and Analysis, 3rd Edition, 2020
6	Ammonia (NH ₃)	BDL	µg/m ³	≤ 400	Method 401, Air Sampling and Analysis 3rd Edition, 2020
7	Lead (Pb)	BDL	µg/m ³	≤ 01	Air Sampling and Analysis, 3rd Edition, 2020
8	Arsenic (As)	BDL	ng/m ³	≤ 06	
9	Nickel (Ni)	BDL	ng/m ³	≤ 20	
10	Carbon Monoxide (CO)	0.39	mg/m ³	≤ 04	GC FID Methanizer Method
11	Benzo(a)Pyrene (BaP)	BDL	ng/m ³	≤ 1.0	IS 5182 Part 12
12	Benzene(C ₆ H ₆)	BDL	µg/m ³	≤ 05	IS 5182 Part 11

Remark- All above results are within National Ambient Air Quality standards.

BDL – Bellow Detection Limit.

Terms and Conditions


- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.


Reviewed By
(Ms. Kalyani Gore)




Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Verified By
Date: 
Department EHS

Page 1 of 1

TEST REPORT (Ambient Air)

Report No.	NLES/25-26/10/AA/RE/539	Report Issue Date	17/10/2025		
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802				
Discipline	Chemical	Date & Time of Sampling	09/10/2025 Time: 11:50		
Group	Atmospheric Pollution	Date of receipt of sample in lab	11/10/2025		
Sub Group	Ambient Air	Sampling Procedure	IS 5182 Part 5		
Sampling Location	Backside of API-9 Building	Dry bulb temperature	31 °C		
Wet bulb temperature	27 °C	Relative Humidity	73 %		
Sampling done by	M/s VSK Enviro Solution				
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025		
Name of Instrument	Ambient Air Combo Sampler 98	Date of Calibration	28/11/2024		
Calibration Certificate No.	SSEC/FF/3585	Due Date of Calibration	27/11/2025		
Results					
Sr. No.	Parameters	Results	Unit(s)	Specifications (NAAQ Standards)	Methods
1	Sulphur Dioxide (SO ₂)	18.5	µg/m ³	≤ 80	IS 5182 (Part 2)
2	Oxides of Nitrogen (NO ₂)	22.7	µg/m ³	≤ 80	IS 5182 (Part 6)
3	Particulate Matter PM ₁₀	50.4	µg/m ³	≤ 100	IS 5182 (Part 4), 1999
4	Particulate Matter PM _{2.5}	17.6	µg/m ³	≤ 60	IS 5182 (Part 24), 2019
5	Ozone (O ₃)	19.69	µg/m ³	≤ 180	Method 411, Air Sampling and Analysis, 3rd Edition, 2020
6	Ammonia (NH ₃)	BDL	µg/m ³	≤ 400	Method 401, Air Sampling and Analysis 3rd Edition, 2020
7	Lead (Pb)	BDL	µg/m ³	≤ 01	Air Sampling and Analysis, 3rd Edition, 2020
8	Arsenic (As)	BDL	ng/m ³	≤ 06	
9	Nickel (Ni)	BDL	ng/m ³	≤ 20	
10	Carbon Monoxide (CO)	0.39	mg/m ³	≤ 04	GC FID Methanizer Method
11	Benzo(a)Pyrene (BaP)	BDL	ng/m ³	≤ 1.0	IS 5182 Part 12
12	Benzene(C ₆ H ₆)	BDL	µg/m ³	≤ 05	IS 5182 Part 11
Remark- All above results are within National Ambient Air Quality standards. BDL – Bellow Detection Limit.					

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Verified By *[Signature]*
Date: *01/11/25*
Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :

ISO 9001 : 2015

ISO 14001 : 2015

ISO 45001 : 2018

TEST REPORT (Ambient Air)

Report No.	NLES/25-26/10/AA/RE/540	Report Issue Date	17/10/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Date & Time of Sampling	09/10/2025 Time: 11:10
Group	Atmospheric Pollution	Date of receipt of sample in lab	11/10/2025
Sub Group	Ambient Air	Sampling Procedure	IS 5182 Part 5
Sampling Location	Near Boiler House	Dry bulb temperature	31 °C
Wet bulb temperature	27 °C	Relative Humidity	73 %
Sampling done by	M/s VSK Enviro Solution		
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025
Name of Instrument	Ambient Air Combo Sampler 99	Date of Calibration	28/11/2024
Calibration Certificate No.	SSEC/FF/3584	Due Date of Calibration	27/11/2025

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (NAAQ Standards)	Methods
1	Sulphur Dioxide (SO ₂)	19.5	µg/m ³	≤ 80	IS 5182 (Part 2)
2	Oxides of Nitrogen (NO ₂)	23.2	µg/m ³	≤ 80	IS 5182 (Part 6)
3	Particulate Matter PM ₁₀	52.4	µg/m ³	≤ 100	IS 5182 (Part 4), 1999
4	Particulate Matter PM _{2.5}	18.8	µg/m ³	≤ 60	IS 5182 (Part 24), 2019
5	Ozone (O ₃)	19.74	µg/m ³	≤ 180	Method 411, Air Sampling and Analysis, 3rd Edition, 2020
6	Ammonia (NH ₃)	BDL	µg/m ³	≤ 400	Method 401, Air Sampling and Analysis 3rd Edition, 2020
7	Lead (Pb)	BDL	µg/m ³	≤ 01	Air Sampling and Analysis, 3rd Edition, 2020
8	Arsenic (As)	BDL	ng/m ³	≤ 06	
9	Nickel (Ni)	BDL	ng/m ³	≤ 20	
10	Carbon Monoxide (CO)	0.38	mg/m ³	≤ 04	GC FID Methanizer Method
11	Benzo(a)Pyrene (BaP)	BDL	ng/m ³	≤ 1.0	IS 5182 Part 12
12	Benzene(C ₆ H ₆)	BDL	µg/m ³	≤ 05	IS 5182 Part 11

Remark- All above results are within National Ambient Air Quality standards.

BDL – Bellow Detection Limit.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.


Reviewed By
(Ms. Kalyani Gore)




Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Verified By

Date:

Department EHS


09/11/25

Page 1 of 1

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501
 Website : www.neetalenvirolab.com, Mob. 8669699854 / 52
 Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
 ISO 9001 : 2015
 ISO 14001 : 2015
 ISO 45001 : 2018

TEST REPORT (Ambient Air)					
Report No.	NLES/25-26/01/AA/RE/810		Report Issue Date	23/01/2026	
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802				
Discipline	Chemical	Date & Time of Sampling	14/01/2026 Time: 10:20		
Group	Atmospheric Pollution	Date of receipt of sample in lab	16/01/2026		
Sub Group	Ambient Air	Sampling Procedure	IS 5182 Part 5		
Sampling Location	Near Main Gate	Dry bulb temperature	30 °C		
Wet bulb temperature	21 °C	Relative Humidity	44 %		
Sampling done by	M/s VSK Enviro Solution				
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026		
Name of Instrument	Ambient Air Combo Sampler 75	Date of Calibration	16/03/2025		
Calibration Certificate No.	SSEC/FF/735	Due Date of Calibration	15/03/2026		
Results					
Sr. No.	Parameters	Results	Unit(s)	Specifications (NAAQ Standards)	Methods
1	Sulphur Dioxide (SO ₂)	19.5	µg/m ³	≤ 80	IS 5182 (Part 2)
2	Oxides of Nitrogen (NO ₂)	23.6	µg/m ³	≤ 80	IS 5182 (Part 6)
3	Particulate Matter PM ₁₀	53.9	µg/m ³	≤ 100	IS 5182 (Part 4), 1999
4	Particulate Matter PM _{2.5}	19.8	µg/m ³	≤ 60	IS 5182 (Part 24), 2019
5	Ozone (O ₃)	19.48	µg/m ³	≤ 180	IS 5182 (Part 9)
6	Ammonia (NH ₃)	BDL	µg/m ³	≤ 400	IS 5182 (Part 25)
7	Lead (Pb)	BDL	µg/m ³	≤ 01	Air Sampling and Analysis, 3rd Edition, 2020
8	Arsenic (As)	BDL	ng/m ³	≤ 06	
9	Nickel (Ni)	BDL	ng/m ³	≤ 20	
10	Carbon Monoxide (CO)	0.41	mg/m ³	≤ 04	IS 5182 Part 10
11	Benzo(a)Pyrene (BaP)	BDL	ng/m ³	≤ 1.0	IS 5182 Part 12
12	Benzene(C ₆ H ₆)	BDL	µg/m ³	≤ 05	IS 5182 Part 11
Remark- All above results are within National Ambient Air Quality standards. BDL – Bellow Detection Limit.					

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
 Reviewed By
 (Ms. Kalyani Gore)



Abhishek
 Authorized Signatory
 (Mr. Abhishek Tope)

*****End of Report*****

Verified By
 Date: *26.02.26*
 Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Ambient Air)

Report No.	NLES/25-26/01/AA/RE/811	Report Issue Date	23/01/2026
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Date & Time of Sampling	14/01/2026 Time: 10:05
Group	Atmospheric Pollution	Date of receipt of sample in lab	16/01/2026
Sub Group	Ambient Air	Sampling Procedure	IS 5182 Part 5
Sampling Location	Near ETP Office Front Side	Dry bulb temperature	30 °C
Wet bulb temperature	21 °C	Relative Humidity	44 %
Sampling done by	M/s VSK Enviro Solution		
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026
Name of Instrument	Ambient Air Combo Sampler 76	Date of Calibration	16/03/2025
Calibration Certificate No.	SSEC/FF/736	Due Date of Calibration	15/03/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (NAAQ Standards)	Methods
1	Sulphur Dioxide (SO ₂)	18.9	µg/m ³	≤ 80	IS 5182 (Part 2)
2	Oxides of Nitrogen (NO ₂)	23.2	µg/m ³	≤ 80	IS 5182 (Part 6)
3	Particulate Matter PM ₁₀	50.5	µg/m ³	≤ 100	IS 5182 (Part 4), 1999
4	Particulate Matter PM _{2.5}	17.7	µg/m ³	≤ 60	IS 5182 (Part 24), 2019
5	Ozone (O ₃)	19.59	µg/m ³	≤ 180	IS 5182 (Part 9)
6	Ammonia (NH ₃)	BDL	µg/m ³	≤ 400	IS 5182 (Part 25)
7	Lead (Pb)	BDL	µg/m ³	≤ 01	Air Sampling and Analysis, 3rd Edition, 2020
8	Arsenic (As)	BDL	ng/m ³	≤ 06	
9	Nickel (Ni)	BDL	ng/m ³	≤ 20	
10	Carbon Monoxide (CO)	0.39	mg/m ³	≤ 04	IS 5182 Part 10
11	Benzo(a)Pyrene (BaP)	BDL	ng/m ³	≤ 1.0	IS 5182 Part 12
12	Benzene(C ₆ H ₆)	BDL	µg/m ³	≤ 05	IS 5182 Part 11

Remark- All above results are within National Ambient Air Quality standards.

BDL – Below Detection Limit.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Verified By
Date: *Abhishek* 06.02.26
Department EHS

Page 1 of 1

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501
 Website : www.neetalenvirolab.com, Mob. 8669699854 / 52
 Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
 ISO 9001 : 2015
 ISO 14001 : 2015
 ISO 45001 : 2018

TEST REPORT (Ambient Air)

Report No.	NLES/25-26/01/AA/RE/812	Report Issue Date	23/01/2026
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Date & Time of Sampling	14/01/2026 Time: 11:00
Group	Atmospheric Pollution	Date of receipt of sample in lab	16/01/2026
Sub Group	Ambient Air	Sampling Procedure	IS 5182 Part 5
Sampling Location	Backside of API-9 Building	Dry bulb temperature	30 °C
Wet bulb temperature	21 °C	Relative Humidity	44 %
Sampling done by	M/s VSK Enviro Solution		
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026
Name of Instrument	Ambient Air Combo Sampler 105	Date of Calibration	16/03/2025
Calibration Certificate No.	SSEC/FF/738	Due Date of Calibration	15/03/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (NAAQ Standards)	Methods
1	Sulphur Dioxide (SO ₂)	19.3	µg/m ³	≤ 80	IS 5182 (Part 2)
2	Oxides of Nitrogen (NO ₂)	23.4	µg/m ³	≤ 80	IS 5182 (Part 6)
3	Particulate Matter PM ₁₀	52.7	µg/m ³	≤ 100	IS 5182 (Part 4), 1999
4	Particulate Matter PM _{2.5}	18.4	µg/m ³	≤ 60	IS 5182 (Part 24), 2019
5	Ozone (O ₃)	19.56	µg/m ³	≤ 180	IS 5182 (Part 9)
6	Ammonia (NH ₃)	BDL	µg/m ³	≤ 400	IS 5182 (Part 25)
7	Lead (Pb)	BDL	µg/m ³	≤ 01	Air Sampling and Analysis, 3rd Edition, 2020
8	Arsenic (As)	BDL	ng/m ³	≤ 06	
9	Nickel (Ni)	BDL	ng/m ³	≤ 20	
10	Carbon Monoxide (CO)	0.40	mg/m ³	≤ 04	IS 5182 Part 10
11	Benzo(a)Pyrene (BaP)	BDL	ng/m ³	≤ 1.0	IS 5182 Part 12
12	Benzene(C ₆ H ₆)	BDL	µg/m ³	≤ 05	IS 5182 Part 11

Remark- All above results are within National Ambient Air Quality standards.
 BDL – Bellow Detection Limit.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
 Reviewed By
 (Ms. Kalyani Gore)



Abhishek
 Authorized Signatory
 (Mr. Abhishek Tope)

*****End of Report*****

Verified By
Aswini
 Date: 06.02.20
 Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Ambient Air)

Report No.	NLES/25-26/01/AA/RE/813	Report Issue Date	23/01/2026
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Date & Time of Sampling	14/01/2026 Time: 10:35
Group	Atmospheric Pollution	Date of receipt of sample in lab	16/01/2026
Sub Group	Ambient Air	Sampling Procedure	IS 5182 Part 5
Sampling Location	Near Boiler House	Dry bulb temperature	30 °C
Wet bulb temperature	21 °C	Relative Humidity	44 %
Sampling done by	M/s VSK Enviro Solution		
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026
Name of Instrument	Ambient Air Combo Sampler 99	Date of Calibration	09/10/2025
Calibration Certificate No.	SSEC/FF/2604	Due Date of Calibration	08/10/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (NAAQ Standards)	Methods
1	Sulphur Dioxide (SO ₂)	19.1	µg/m ³	≤ 80	IS 5182 (Part 2)
2	Oxides of Nitrogen (NO ₂)	22.6	µg/m ³	≤ 80	IS 5182 (Part 6)
3	Particulate Matter PM ₁₀	51.0	µg/m ³	≤ 100	IS 5182 (Part 4), 1999
4	Particulate Matter PM _{2.5}	18.3	µg/m ³	≤ 60	IS 5182 (Part 24), 2019
5	Ozone (O ₃)	19.69	µg/m ³	≤ 180	IS 5182 (Part 9)
6	Ammonia (NH ₃)	BDL	µg/m ³	≤ 400	IS 5182 (Part 25)
7	Lead (Pb)	BDL	µg/m ³	≤ 01	Air Sampling and Analysis, 3rd Edition, 2020
8	Arsenic (As)	BDL	ng/m ³	≤ 06	
9	Nickel (Ni)	BDL	ng/m ³	≤ 20	
10	Carbon Monoxide (CO)	0.37	mg/m ³	≤ 04	IS 5182 Part 10
11	Benzo(a)Pyrene (BaP)	BDL	ng/m ³	≤ 1.0	IS 5182 Part 12
12	Benzene(C ₆ H ₆)	BDL	µg/m ³	≤ 05	IS 5182 Part 11

Remark- All above results are within National Ambient Air Quality standards.

BDL – Bellow Detection Limit.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Verified By
Date: *Abhishek*
06.02.26
Department EHS

Page 1 of 1

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/01/ST/RE/827	Report Issue Date	23/01/2026
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: MS
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Rectangle
Date of Sampling	14/01/2026	Sampling Location	(S42) Dust Collector-1402 API-IV
Time of Sampling	17:45	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026
Name of Instrument	Stack Sampling Kit-107	Date of Calibration	08/10/2025
Calibration Certificate No.	SSEC/TH/303	Due Date of Calibration	07/10/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	326	°K	--	--
2	Differential Pressure	3.4	mm WG		
3	Velocity	6.32	M/s		
4	Dimensions of Stack	0.22 X 0.20	Mtr.		
5	Stack Area	0.044	M ²		
6	Gas Volume	915.10	Nm ³ /Hr		
7	Total Particulate Matter	17.12	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	ND	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	BDL	mg/Nm ³	N.S.	OSHA 165 SG

Remark.


- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.


Reviewed By
(Ms. Kalyani Gore)




Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Page 1 of 1

Verified By
Date: 
06.02.26
Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/01/ST/RE/828	Report Issue Date	23/01/2026
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: MS
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Square
Date of Sampling	14/01/2026	Sampling Location	(S43) Dust Collector-1403 API-IV
Time of Sampling	17:40	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026
Name of Instrument	Stack Sampling Kit – 01	Date of Calibration	06/05/2025
Calibration Certificate No.	SSEC/FF/1173	Due Date of Calibration	05/05/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	332	°K	--	--
2	Differential Pressure	3.3	mm WG		
3	Velocity	6.28	M/s		
4	Dimensions of Stack	0.17 X 0.17	Mtr.		
5	Stack Area	0.0289	M ²		
6	Gas Volume	586.46	Nm ³ /Hr		
7	Total Particulate Matter	18.04	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	ND	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	BDL	mg/Nm ³	N.S.	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Page 1 of 1

Verified By
Date: *06.02.26*
Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/01/ST/RE/829	Report Issue Date	23/01/2026
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: MS
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Square
Date of Sampling	15/01/2026	Sampling Location	(S44) Dust Collector-1301 API-V
Time of Sampling	13:20	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026
Name of Instrument	Stack Sampling Kit-107	Date of Calibration	08/10/2025
Calibration Certificate No.	SSEC/TH/303	Due Date of Calibration	07/10/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	336	°K		
2	Differential Pressure	3.5	mm WG		
3	Velocity	6.51	M/s		
4	Dimensions of Stack	0.60 X 0.60	Mtr.		
5	Stack Area	0.36	M ²		
6	Gas Volume	7482.78	Nm ³ /Hr		
7	Total Particulate Matter	13.18	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	ND	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	BDL	mg/Nm ³	N.S.	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Page 1 of 1

Verified By
Date: *06.02.26*
Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501
Website : www.neetalenvirolab.com, Mob. 8669699854 / 52
Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/01/ST/RE/830	Report Issue Date	23/01/2026
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: MS
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Rectangle
Date of Sampling	15/01/2026	Sampling Location	(S45) Dust Collector-1302 API-V
Time of Sampling	14:00	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026
Name of Instrument	Stack Sampling Kit - 01	Date of Calibration	06/05/2025
Calibration Certificate No.	SSEC/FF/1173	Due Date of Calibration	05/05/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	333	°K	--	--
2	Differential Pressure	3.5	mm WG		
3	Velocity	6.48	M/s		
4	Dimensions of Stack	0.13 X 0.15	Mtr.		
5	Stack Area	0.0195	M ²		
6	Gas Volume	407.08	Nm ³ /Hr		
7	Total Particulate Matter	13.72	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	ND	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	BDL	mg/Nm ³	N.S.	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Page 1 of 1

Verified By
Date: *06.02.26*
Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/01/ST/RE/824	Report Issue Date	23/01/2026
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: MS
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Rectangle
Date of Sampling	15/01/2026	Sampling Location	(S39) API-I Dust Collector-101
Time of Sampling	09:35	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026
Name of Instrument	Stack Sampling Kit-107	Date of Calibration	08/10/2025
Calibration Certificate No.	SSEC/TH/303	Due Date of Calibration	07/10/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	322	°K	--	--
2	Differential Pressure	3.2	mm WG		
3	Velocity	6.09	M/s		
4	Dimensions of Stack	0.25 X 0.30	Mtr.		
5	Stack Area	0.075	M ²		
6	Gas Volume	1521.74	Nm ³ /Hr		
7	Total Particulate Matter	14.40	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	ND	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	BDL	mg/Nm ³	N.S.	OSHA 165 SG

Remark.


- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.


Reviewed By
(Ms. Kalyani Gore)




Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Page 1 of 1

Verified By
Date: 
06.02.26
Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/01/ST/RE/825	Report Issue Date	23/01/2026
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: MS
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Square
Date of Sampling	15/01/2026	Sampling Location	(S40) Dust Collector -301 API-III
Time of Sampling	12:10	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026
Name of Instrument	Stack Sampling Kit - 01	Date of Calibration	06/05/2025
Calibration Certificate No.	SSEC/FF/1173	Due Date of Calibration	05/05/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	312	°K	--	--
2	Differential Pressure	3.1	mm WG		
3	Velocity	5.90	M/s		
4	Dimensions of Stack	0.38 X 0.38	Mtr.		
5	Stack Area	0.1444	M ²		
6	Gas Volume	2929.43	Nm ³ /Hr		
7	Total Particulate Matter	10.15	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	ND	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	BDL	mg/Nm ³	N.S.	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Page 1 of 1

Verified By
Date: *06.02.26*
Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501
 Website : www.neetalenvirolab.com, Mob. 8669699854 / 52
 Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
 ISO 9001 : 2015
 ISO 14001 : 2015
 ISO 45001 : 2018

TEST REPORT (Stack Emission)					
Report No.	NLES/25-26/01/ST/RE/826	Report Issue Date	23/01/2026		
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802				
Discipline	Chemical	Sample Description	Stack Material: MS		
Group	Pollution & Environment.		Stack Height: 10.0 Mtr		
Sub Group	Stack Emission.		Stack Type: Square		
Date of Sampling	14/01/2026	Sampling Location	(S41) Dust Collector-1401 API-IV		
Time of Sampling	17:10	Sampling duration	30 Min		
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring		
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026		
Name of Instrument	Stack Sampling Kit - 01	Date of Calibration	06/05/2025		
Calibration Certificate No.	SSEC/FF/1173	Due Date of Calibration	05/05/2026		
Results					
Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	318	°K	--	--
2	Differential Pressure	3.3	mm WG		
3	Velocity	6.15	M/s		
4	Dimensions of Stack	0.25 X 0.25	Mtr.		
5	Stack Area	0.0625	M ²		
6	Gas Volume	1296.72	Nm ³ /Hr		
7	Total Particulate Matter	19.12	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	ND	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	BDL	mg/Nm ³	N.S.	OSHA 165 SG
Remark.					
<ul style="list-style-type: none"> All above results are well within MPCB Limit. N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected. 					

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
 Reviewed By
 (Ms. Kalyani Gore)



Abhishek
 Authorized Signatory
 (Mr. Abhishek Tope)

*****End of Report*****

Verified By
 Date: *06.02.26*
 Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/01/ST/RE/831	Report Issue Date	23/01/2026
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: MS
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Rectangle
Date of Sampling	14/01/2026	Sampling Location	(S46) Dust Collector-1601 API-VI
Time of Sampling	16:28	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026
Name of Instrument	Stack Sampling Kit-107	Date of Calibration	08/10/2025
Calibration Certificate No.	SSEC/TH/303	Due Date of Calibration	07/10/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	351	°K	--	--
2	Differential Pressure	4.2	mm WG		
3	Velocity	7.29	M/s		
4	Dimensions of Stack	0.18 X 0.22	Mtr.		
5	Stack Area	0.0396	M ²		
6	Gas Volume	882.34	Nm ³ /Hr		
7	Total Particulate Matter	16.16	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	ND	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	BDL	mg/Nm ³	N.S.	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Page 1 of 1

Verified By
Date: *06.02.26*
Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/01/ST/RE/832	Report Issue Date	23/01/2026
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: MS
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Square
Date of Sampling	14/01/2026	Sampling Location	(S47) Dust Collector-1701 API-VII
Time of Sampling	16:30	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026
Name of Instrument	Stack Sampling Kit-107	Date of Calibration	08/10/2025
Calibration Certificate No.	SSEC/TH/303	Due Date of Calibration	07/10/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	327	°K	--	--
2	Differential Pressure	3.6	mm WG		
3	Velocity	6.51	M/s		
4	Dimensions of Stack	0.30 X 0.30	Mtr.		
5	Stack Area	0.09	M ²		
6	Gas Volume	1922.18	Nm ³ /Hr		
7	Total Particulate Matter	17.40	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	ND	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	BDL	mg/Nm ³	N.S.	OSHA 165 SG

Remark.


- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.


Reviewed By
(Ms. Kalyani Gore)




Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Page 1 of 1

Verified By
Date:  06.02.26
Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501
Website : www.neetalenvirolab.com, Mob. 8669699854 / 52
Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/01/ST/RE/833	Report Issue Date	23/01/2026
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: MS
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Square
Date of Sampling	14/01/2026	Sampling Location	(S48) Dust Collector-1709 API-VII
Time of Sampling	14:35	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026
Name of Instrument	Stack Sampling Kit - 01	Date of Calibration	06/05/2025
Calibration Certificate No.	SSEC/FF/1173	Due Date of Calibration	05/05/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	336	°K	--	--
2	Differential Pressure	4.0	mm WG		
3	Velocity	6.96	M/s		
4	Dimensions of Stack	0.34 X 0.34	Mtr.		
5	Stack Area	0.1156	M ²		
6	Gas Volume	2568.89	Nm ³ /Hr		
7	Total Particulate Matter	15.40	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	ND	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	BDL	mg/Nm ³	N.S.	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Page 1 of 1

Verified By
Date: *Abhishek* 06.02.26
Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501
Website : www.neetalenvirolab.com, Mob. 8669699854 / 52
Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/01/ST/RE/834	Report Issue Date	23/01/2026
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: MS
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Square
Date of Sampling	14/01/2026	Sampling Location	(S49) Dust Collector-2002 API-VIII
Time of Sampling	10:30	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026
Name of Instrument	Stack Sampling Kit-107	Date of Calibration	08/10/2025
Calibration Certificate No.	SSEC/TH/303	Due Date of Calibration	07/10/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	326	°K	--	--
2	Differential Pressure	3.2	mm WG		
3	Velocity	6.13	M/s		
4	Dimensions of Stack	0.34 X 0.34	Mtr.		
5	Stack Area	0.1156	M ²		
6	Gas Volume	2331.95	Nm ³ /Hr		
7	Total Particulate Matter	11.15	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	ND	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	BDL	mg/Nm ³	N.S.	OSHA 165 SG

Remark.


- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.


Reviewed By
(Ms. Kalyani Gore)




Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Page 1 of 1

Verified By
Date: 
06.02.26
Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/01/ST/RE/835	Report Issue Date	23/01/2026
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: MS
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Rectangle
Date of Sampling	14/01/2026	Sampling Location	(S50) Warehouse Dust Collector 901
Time of Sampling	16:55	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026
Name of Instrument	Stack Sampling Kit – 01	Date of Calibration	06/05/2025
Calibration Certificate No.	SSEC/FF/1173	Due Date of Calibration	05/05/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	320	°K	--	--
2	Differential Pressure	3.3	mm WG		
3	Velocity	6.17	M/s		
4	Dimensions of Stack	0.36 X 0.30	Mtr.		
5	Stack Area	0.108	M ²		
6	Gas Volume	2233.97	Nm ³ /Hr		
7	Total Particulate Matter	15.43	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	ND	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	BDL	mg/Nm ³	N.S.	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Page 1 of 1

Verified By
Date: *06.02.26*
Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :

ISO 9001 : 2015

ISO 14001 : 2015

ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/01/ST/RE/861	Report Issue Date	23/01/2026
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: MS
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Square
Date of Sampling	14/01/2026	Sampling Location	(S51) Dust Collector-2101 API -IX
Time of Sampling	14:00	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026
Name of Instrument	Stack Sampling Kit - 01	Date of Calibration	06/05/2025
Calibration Certificate No.	SSEC/FF/1173	Due Date of Calibration	05/05/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	338	°K	--	--
2	Differential Pressure	4.1	mm WG		
3	Velocity	7.07	M/s		
4	Dimensions of Stack	0.52 X 0.52	Mtr.		
5	Stack Area	0.2704	M ²		
6	Gas Volume	6067.76	Nm ³ /Hr		
7	Total Particulate Matter	13.72	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	ND	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	BDL	mg/Nm ³	N.S.	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Page 1 of 1

Verified By
Date: *Neel*
06.02.26
Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501
Website : www.neetalenvirolab.com, Mob. 8669699854 / 52
Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/01/ST/RE/862	Report Issue Date	23/01/2026
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: MS
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Rectangle
Date of Sampling	15/01/2026	Sampling Location	(S52) Dust Collector-201 API -II
Time of Sampling	11:25	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026
Name of Instrument	Stack Sampling Kit - 01	Date of Calibration	06/05/2025
Calibration Certificate No.	SSEC/FF/1173	Due Date of Calibration	05/05/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	332	°K	--	--
2	Differential Pressure	3.4	mm WG		
3	Velocity	6.38	M/s		
4	Dimensions of Stack	0.35 X 0.40	Mtr.		
5	Stack Area	0.140	M ²		
6	Gas Volume	2886.22	Nm ³ /Hr		
7	Total Particulate Matter	13.16	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	ND	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	BDL	mg/Nm ³	N.S.	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.


Reviewed By
(Ms. Kalyani Gore)




Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Page 1 of 1

Verified By
Date:  06.02.26
Department EHS

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/10/ST/RE/589	Report Issue Date	17/10/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: MS
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Rectangle
Date of Sampling	10/10/2025	Sampling Location	(S52) Dust Collector-201 API-II
Time of Sampling	14:55	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025
Name of Instrument	Stack Sampling Kit – 01	Date of Calibration	06/05/2025
Calibration Certificate No.	SSEC/FF/1173	Due Date of Calibration	05/05/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	325	°K	--	--
2	Differential Pressure	3.7	mm WG		
3	Velocity	6.58	M/s		
4	Dimensions of Stack	0.35 X 0.40	Mtr.		
5	Stack Area	0.140	M ²		
6	Gas Volume	3040.81	Nm ³ /Hr		
7	Total Particulate Matter	12.26	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	ND	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	BDL	mg/Nm ³	N.S.	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
 Reviewed By
 (Ms. Kalyani Gore)



Abhishek
 Authorized Signatory
 (Mr. Abhishek Tope)

*****End of Report*****

Verified By *[Signature]*
 Date: 01.11.25
 Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501
 Website : www.neetalenvirolab.com, Mob. 8669699854 / 52
 Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
 ISO 9001 : 2015
 ISO 14001 : 2015
 ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/10/ST/RE/588	Report Issue Date	17/10/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: MS
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Square
Date of Sampling	09/10/2025	Sampling Location	(S51) Dust Collector-2101 API -IX
Time of Sampling	17:35	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025
Name of Instrument	Stack Sampling Kit - 01	Date of Calibration	06/05/2025
Calibration Certificate No.	SSEC/FF/1173	Due Date of Calibration	05/05/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	332	°K	--	--
2	Differential Pressure	4.0	mm WG		
3	Velocity	6.92	M/s		
4	Dimensions of Stack	0.52 X 0.52	Mtr.		
5	Stack Area	0.2704	M ²		
6	Gas Volume	6046.35	Nm ³ /Hr		
7	Total Particulate Matter	14.69	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	ND	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	BDL	mg/Nm ³	N.S.	OSHA 165 SG

Remark.

- All above results are well within MPCB limit
- N.S - Not Specified, BDL - Below Detection Limit & ND - Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
 Reviewed By
 (Ms. Kalyani Gore)



Abhishek
 Authorized Signatory
 (Mr. Abhishek Tope)

*****End of Report*****

Verified By *B*
 Date: *21.11.25*
 Department EHS

TEST REPORT (Stack Emission)					
Report No.	NLES/25-26/10/ST/RE/562	Report Issue Date	17/10/2025		
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802				
Discipline	Chemical	Sample Description	Stack Material: MS		
Group	Pollution & Environment.		Stack Height: 10.0 Mtr		
Sub Group	Stack Emission		Stack Type: Rectangle		
Date of Sampling	09/10/2025	Sampling Location	(S50) Warehouse Dust Collector 901		
Time of Sampling	16:25	Sampling duration	30 Min		
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring		
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025		
Name of Instrument	Stack Sampling Kit – 01	Date of Calibration	06/05/2025		
Calibration Certificate No.	SSEC/FF/1173	Due Date of Calibration	05/05/2026		
Results					
Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	327	°K	--	--
2	Differential Pressure	3.4	mm WG		
3	Velocity	6.33	M/s		
4	Dimensions of Stack	0.36 X 0.30	Mtr.		
5	Stack Area	0.108	M ²		
6	Gas Volume	2242.84	Nm ³ /Hr		
7	Total Particulate Matter	16.05	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	ND	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	BDL	mg/Nm ³	N.S.	OSHA 165 SG
Remark.					
<ul style="list-style-type: none"> All above results are well within MPCB Limit. N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected. 					

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
 Reviewed By
 (Ms. Kalyani Gore)



Abhishek
 Authorized Signatory
 (Mr. Abhishek Tope)

*****End of Report*****

Verified By *[Signature]*
 Date: *01/11/25*
 Department EHS

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/10/ST/RE/561	Report Issue Date	17/10/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: MS
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Square
Date of Sampling	09/10/2025	Sampling Location	(S49) Dust Collector-2002 API-VIII
Time of Sampling	16:05	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025
Name of Instrument	Stack Sampling Kit-107	Date of Calibration	08/10/2025
Calibration Certificate No.	SSEC/TH/303	Due Date of Calibration	07/10/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	329	°K	--	--
2	Differential Pressure	3.5	mm WG		
3	Velocity	6.44	M/s		
4	Dimensions of Stack	0.34 X 0.34	Mtr.		
5	Stack Area	0.1156	M ²		
6	Gas Volume	2427.54	Nm ³ /Hr		
7	Total Particulate Matter	12.57	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	ND	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	BDL	mg/Nm ³	N.S.	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
 Reviewed By
 (Ms. Kalyani Gore)



Abhishek
 Authorized Signatory
 (Mr. Abhishek Tope)

*****End of Report*****

Verified By *PD*
 Date: *01.11.25*
 Department EHS

Page 1 of 1

TEST REPORT (Stack Emission)			
Report No.	NLES/25-26/10/ST/RE/560	Report Issue Date	17/10/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: MS
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Square
Date of Sampling	10/10/2025	Sampling Location	(S48) Dust Collector-1709 API-VII
Time of Sampling	16:40	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025
Name of Instrument	Stack Sampling Kit - 01	Date of Calibration	06/05/2025
Calibration Certificate No.	SSEC/FF/1173	Due Date of Calibration	05/05/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	341	°K	--	--
2	Differential Pressure	4.2	mm WG		
3	Velocity	7.19	M/s		
4	Dimensions of Stack	0.34 X 0.34	Mtr.		
5	Stack Area	0.1156	M ²		
6	Gas Volume	2614.88	Nm ³ /Hr		
7	Total Particulate Matter	16.85	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	ND	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	BDL	mg/Nm ³	N.S.	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
 Reviewed By
 (Ms. Kalyani Gore)



Abhishek
 Authorized Signatory
 (Mr. Abhishek Tope)

*****End of Report*****

Verified By *[Signature]*
 Date: 01.11.25
 Department EHS

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/10/ST/RE/559	Report Issue Date	17/10/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: MS
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Square
Date of Sampling	10/10/2025	Sampling Location	(S47) Dust Collector-1701 API-VII
Time of Sampling	16:20	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025
Name of Instrument	Stack Sampling Kit-107	Date of Calibration	08/10/2025
Calibration Certificate No.	SSEC/TH/303	Due Date of Calibration	07/10/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	332	°K	--	--
2	Differential Pressure	3.7	mm WG		
3	Velocity	6.66	M/s		
4	Dimensions of Stack	0.30 X 0.30	Mtr.		
5	Stack Area	0.09	M ²		
6	Gas Volume	1936.86	Nm ³ /Hr		
7	Total Particulate Matter	18.23	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	ND	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	BDL	mg/Nm ³	N.S.	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
 Reviewed By
 (Ms. Kalyani Gore)



Abhishek
 Authorized Signatory
 (Mr. Abhishek Tope)

Verified By *[Signature]*
 Date: 07.11.25
 Department EHS

*****End of Report*****

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/10/ST/RE/558	Report Issue Date	17/10/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: MS
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Rectangle
Date of Sampling	09/10/2025	Sampling Location	(S46) Dust Collector-1601 API-VI
Time of Sampling	12:15	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025
Name of Instrument	Stack Sampling Kit-107	Date of Calibration	08/10/2025
Calibration Certificate No.	SSEC/TH/303	Due Date of Calibration	07/10/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	354	°K	--	--
2	Differential Pressure	4.4	mm WG		
3	Velocity	7.49	M/s		
4	Dimensions of Stack	0.18 X 0.22	Mtr.		
5	Stack Area	0.0396	M ²		
6	Gas Volume	898.86	Nm ³ /Hr		
7	Total Particulate Matter	17.81	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	ND	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	BDL	mg/Nm ³	N.S.	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
 Reviewed By
 (Ms. Kalyani Gore)



Abhishek
 Authorized Signatory
 (Mr. Abhishek Tope)

*****End of Report*****

Verified By *B*
 Date: *21/11/25*
 Department EHS

TEST REPORT (Stack Emission)					
Report No.	NLES/25-26/10/ST/RE/557	Report Issue Date	17/10/2025		
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802				
Discipline	Chemical	Sample Description	Stack Material: MS		
Group	Pollution & Environment.		Stack Height: 10.0 Mtr		
Sub Group	Stack Emission		Stack Type: Rectangle		
Date of Sampling	10/10/2025	Sampling Location	(S45) Dust Collector-1302 API-V		
Time of Sampling	10:50	Sampling duration	30 Min		
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring		
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025		
Name of Instrument	Stack Sampling Kit – 01	Date of Calibration	06/05/2025		
Calibration Certificate No.	SSEC/FF/1173	Due Date of Calibration	05/05/2026		
Results					
Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	336	°K	--	--
2	Differential Pressure	3.2	mm WG		
3	Velocity	6.23	M/s		
4	Dimensions of Stack	0.13 X 0.15	Mtr.		
5	Stack Area	0.0195	M ²		
6	Gas Volume	387.88	Nm ³ /Hr		
7	Total Particulate Matter	14.90	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	ND	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	BDL	mg/Nm ³	N.S.	OSHA 165 SG
Remark.					
<ul style="list-style-type: none"> All above results are well within MPCB Limit. N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected. 					

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
 Reviewed By
 (Ms. Kalyani Gore)



Abhishek
 Authorized Signatory
 (Mr. Abhishek Tope)

*****End of Report*****

Verified By *[Signature]*
 Date: *01.11.25*
 Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/10/ST/RE/556	Report Issue Date	17/10/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: MS
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Square
Date of Sampling	10/10/2025	Sampling Location	(S44) Dust Collector-1301 API-V
Time of Sampling	10:25	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025
Name of Instrument	Stack Sampling Kit-107	Date of Calibration	08/10/2025
Calibration Certificate No.	SSEC/TH/303	Due Date of Calibration	07/10/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	336	°K	--	--
2	Differential Pressure	3.4	mm WG		
3	Velocity	6.42	M/s		
4	Dimensions of Stack	0.60 X 0.60	Mtr.		
5	Stack Area	0.36	M ²		
6	Gas Volume	7379.33	Nm ³ /Hr		
7	Total Particulate Matter	11.28	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	ND	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	BDL	mg/Nm ³	N.S.	OSHA 165 SG

Remark.


- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.


Reviewed By
(Ms. Kalyani Gore)




Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Verified By 
Date: 
Department EHS

Page 1 of 1

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501
Website : www.neetalenvirolab.com, Mob. 8669699854 / 52
Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/10/ST/RE/555	Report Issue Date	17/10/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: MS
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Square
Date of Sampling	10/10/2025	Sampling Location	(S43) Dust Collector-1403 API-IV
Time of Sampling	10:15	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025
Name of Instrument	Stack Sampling Kit - 01	Date of Calibration	06/05/2025
Calibration Certificate No.	SSEC/FF/1173	Due Date of Calibration	05/05/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	339	°K	--	--
2	Differential Pressure	3.4	mm WG		
3	Velocity	6.44	M/s		
4	Dimensions of Stack	0.17 X 0.17	Mtr.		
5	Stack Area	0.0289	M ²		
6	Gas Volume	588.98	Nm ³ /Hr		
7	Total Particulate Matter	20.90	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	ND	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	BDL	mg/Nm ³	N.S.	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions


- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.


Reviewed By
(Ms. Kalyani Gore)




Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Verified By 
Date: 01/11/25
Department EHS

Page 1 of 1

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/10/ST/RE/554	Report Issue Date	17/10/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: MS
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Rectangle
Date of Sampling	10/10/2025	Sampling Location	(S42) Dust Collector-1402 API-IV
Time of Sampling	09:50	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025
Name of Instrument	Stack Sampling Kit-107	Date of Calibration	08/10/2025
Calibration Certificate No.	SSEC/TH/303	Due Date of Calibration	07/10/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	321	°K	--	--
2	Differential Pressure	3.7	mm WG		
3	Velocity	6.54	M/s		
4	Dimensions of Stack	0.22 X 0.20	Mtr.		
5	Stack Area	0.044	M ²		
6	Gas Volume	961.71	Nm ³ /Hr		
7	Total Particulate Matter	17.12	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	ND	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	BDL	mg/Nm ³	N.S.	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
 Reviewed By
 (Ms. Kalyani Gore)



Abhishek
 Authorized Signatory
 (Mr. Abhishek Tope)

*****End of Report*****

Verified By *[Signature]*
 Date: 01.11.25
 Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/10/ST/RE/553	Report Issue Date	17/10/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: MS
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Square
Date of Sampling	10/10/2025	Sampling Location	(S41) Dust Collector-1401 API-IV
Time of Sampling	09:40	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025
Name of Instrument	Stack Sampling Kit - 01	Date of Calibration	06/05/2025
Calibration Certificate No.	SSEC/FF/1173	Due Date of Calibration	05/05/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	319	°K	--	--
2	Differential Pressure	3.5	mm WG		
3	Velocity	6.34	M/s		
4	Dimensions of Stack	0.25 X 0.25	Mtr.		
5	Stack Area	0.0625	M ²		
6	Gas Volume	1332.59	Nm ³ /Hr		
7	Total Particulate Matter	20.25	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	ND	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	BDL	mg/Nm ³	N.S.	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions


- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.


Reviewed By
(Ms. Kalyani Gore)




Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Verified By 
Date: 01.11.25
Department EHS

Page 1 of 1

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/10/ST/RE/552	Report Issue Date	17/10/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: MS
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Square
Date of Sampling	10/10/2025	Sampling Location	(S40) Dust Collector -301 API-III
Time of Sampling	15:30	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025
Name of Instrument	Stack Sampling Kit - 01	Date of Calibration	06/05/2025
Calibration Certificate No.	SSEC/FF/1173	Due Date of Calibration	05/05/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	316	°K	--	--
2	Differential Pressure	3.2	mm WG		
3	Velocity	6.04	M/s		
4	Dimensions of Stack	0.38 X 0.38	Mtr.		
5	Stack Area	0.1444	M ²		
6	Gas Volume	2960.98	Nm ³ /Hr		
7	Total Particulate Matter	11.40	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	ND	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	BDL	mg/Nm ³	N.S.	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Verified By *B*
Date: *01/11/25*
Department EHS

Page 1 of 1

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/10/ST/RE/551	Report Issue Date	17/10/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: MS
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Rectangle
Date of Sampling	10/10/2025	Sampling Location	(S39) API-I Dust Collector-101
Time of Sampling	14:00	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025
Name of Instrument	Stack Sampling Kit-107	Date of Calibration	08/10/2025
Calibration Certificate No.	SSEC/TH/303	Due Date of Calibration	07/10/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	327	°K	--	--
2	Differential Pressure	3.4	mm WG		
3	Velocity	6.33	M/s		
4	Dimensions of Stack	0.25 X 0.30	Mtr.		
5	Stack Area	0.075	M ²		
6	Gas Volume	1557.52	Nm ³ /Hr		
7	Total Particulate Matter	16.15	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	ND	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	BDL	mg/Nm ³	N.S.	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Page 1 of 1

Verified By *[Signature]*
Date: 21.11.25
Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :

ISO 9001 : 2015

ISO 14001 : 2015

ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/01/ST/RE/836	Report Issue Date	23/01/2026
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: FRP
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	15/01/2026	Sampling Location	(S7) API-I Scrubber-101
Time of Sampling	10:12	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026
Name of Instrument	Stack Sampling Kit - 01	Date of Calibration	06/05/2025
Calibration Certificate No.	SSEC/FF/1173	Due Date of Calibration	05/05/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	340	°K	--	--
2	Differential Pressure	4.7	mm WG		
3	Velocity	7.59	M/s		
4	Dimensions of Stack	0.50	Mtr.		
5	Stack Area	0.19625	M ²		
6	Gas Volume	4699.93	Nm ³ /Hr		
7	Total Particulate Matter	20.73	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	03.90	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	0.84	mg/Nm ³	≤ 35	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Page 1 of 1

Verified By
Date: *Abheem*
06.02.26
Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501
 Website : www.neetalenvirolab.com, Mob. 8669699854 / 52
 Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
 ISO 9001 : 2015
 ISO 14001 : 2015
 ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/01/ST/RE/837	Report Issue Date	23/01/2026
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: FRP
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	15/01/2026	Sampling Location	(S8) API-II Scrubber-201
Time of Sampling	10:50	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026
Name of Instrument	Stack Sampling Kit-107	Date of Calibration	08/10/2025
Calibration Certificate No.	SSEC/TH/303	Due Date of Calibration	07/10/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	342	°K	--	--
2	Differential Pressure	5.4	mm WG		
3	Velocity	8.16	M/s		
4	Dimensions of Stack	0.30	Mtr.		
5	Stack Area	0.07065	M ²		
6	Gas Volume	1808.40	Nm ³ /Hr		
7	Total Particulate Matter	13.11	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	04.63	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	1.04	mg/Nm ³	≤ 35	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
 Reviewed By
 (Ms. Kalyani Gore)



Abhishek
 Authorized Signatory
 (Mr. Abhishek Tope)

*****End of Report*****

Page 1 of 1

Verified By
 Date: *Abhishek*
 06.02.26
 Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501
Website : www.neetalenvirolab.com, Mob. 8669699854 / 52
Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/01/ST/RE/838	Report Issue Date	23/01/2026
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: FRP
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	15/01/2026	Sampling Location	(S9) API-III Scrubber- 301
Time of Sampling	13:30	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026
Name of Instrument	Stack Sampling Kit-107	Date of Calibration	08/10/2025
Calibration Certificate No.	SSEC/TH/303	Due Date of Calibration	07/10/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	344	°K	--	--
2	Differential Pressure	3.7	mm WG		
3	Velocity	6.77	M/s		
4	Dimensions of Stack	0.50	Mtr.		
5	Stack Area	0.19625	M ²		
6	Gas Volume	4143.42	Nm ³ /Hr		
7	Total Particulate Matter	16.28	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	05.15	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	1.12	mg/Nm ³	≤ 35	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Verified By
Date: *Abhishek*
06.02.26
Department EHS

Page 1 of 1

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501
Website : www.neetalenvirolab.com, Mob. 8669699854 / 52
Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/01/ST/RE/839	Report Issue Date	23/01/2026
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: FRP
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	15/01/2026	Sampling Location	(S10) API-III Scrubber- 302
Time of Sampling	14:15	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026
Name of Instrument	Stack Sampling Kit - 01	Date of Calibration	06/05/2025
Calibration Certificate No.	SSEC/FF/1173	Due Date of Calibration	05/05/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	345	°K	--	--
2	Differential Pressure	3.6	mm WG		
3	Velocity	6.69	M/s		
4	Dimensions of Stack	0.30	Mtr.		
5	Stack Area	0.07065	M ²		
6	Gas Volume	1469.73	Nm ³ /Hr		
7	Total Particulate Matter	14.12	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	04.37	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	0.91	mg/Nm ³	≤ 35	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Page 1 of 1

Verified By
Date: *Heena*
06.02.26
Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/01/ST/RE/840	Report Issue Date	23/01/2026
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: FRP
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	15/01/2026	Sampling Location	(S11) API-III Scrubber- 303
Time of Sampling	15:00	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026
Name of Instrument	Stack Sampling Kit-107	Date of Calibration	08/10/2025
Calibration Certificate No.	SSEC/TH/303	Due Date of Calibration	07/10/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	359	°K	--	--
2	Differential Pressure	3.2	mm WG		
3	Velocity	6.44	M/s		
4	Dimensions of Stack	0.34	Mtr.		
5	Stack Area	0.09075	M ²		
6	Gas Volume	1746.45	Nm ³ /Hr		
7	Total Particulate Matter	13.52	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	05.67	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	0.98	mg/Nm ³	≤ 35	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Page 1 of 1

Verified By
Date: *06-02-26*
Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501
 Website : www.neetalenvirolab.com, Mob. 8669699854 / 52
 Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
 ISO 9001 : 2015
 ISO 14001 : 2015
 ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/01/ST/RE/841	Report Issue Date	23/01/2026
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: FRP
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	14/01/2026	Sampling Location	(S12) Scrubber-1401 API-IV
Time of Sampling	18:20	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026
Name of Instrument	Stack Sampling Kit-107	Date of Calibration	08/10/2025
Calibration Certificate No.	SSEC/TH/303	Due Date of Calibration	07/10/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	329	°K	--	--
2	Differential Pressure	3.4	mm WG		
3	Velocity	6.35	M/s		
4	Dimensions of Stack	0.34	Mtr.		
5	Stack Area	0.09075	M ²		
6	Gas Volume	1879.07	Nm ³ /Hr		
7	Total Particulate Matter	12.18	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	6.46	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	1.19	mg/Nm ³	≤ 35	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
 Reviewed By
 (Ms. Kalyani Gore)



Abhishek
 Authorized Signatory
 (Mr. Abhishek Tope)

*****End of Report*****

Verified By
 Date: *Abhishek*
 06-02-26
 Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501
Website : www.neetalenvirolab.com, Mob. 8669699854 / 52
Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/01/ST/RE/842	Report Issue Date	23/01/2026
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: FRP
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	14/01/2026	Sampling Location	(S13) Scrubber-1402 API-IV
Time of Sampling	18:18	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026
Name of Instrument	Stack Sampling Kit - 01	Date of Calibration	06/05/2025
Calibration Certificate No.	SSEC/FF/1173	Due Date of Calibration	05/05/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	335	°K	--	--
2	Differential Pressure	3.1	mm WG		
3	Velocity	6.12	M/s		
4	Dimensions of Stack	0.34	Mtr.		
5	Stack Area	0.09075	M ²		
6	Gas Volume	1778.57	Nm ³ /Hr		
7	Total Particulate Matter	16.40	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	6.37	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	1.18	mg/Nm ³	≤ 35	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Page 1 of 1

Verified By
Date: *06/02/26*
Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501
Website : www.neetalenvirolab.com, Mob. 8669699854 / 52
Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/01/ST/RE/843	Report Issue Date	23/01/2026
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: FRP
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	15/01/2026	Sampling Location	(S14) Scrubber-1301 API-V
Time of Sampling	09:25	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026
Name of Instrument	Stack Sampling Kit-107	Date of Calibration	08/10/2025
Calibration Certificate No.	SSEC/TH/303	Due Date of Calibration	07/10/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	338	°K	--	--
2	Differential Pressure	3.2	mm WG		
3	Velocity	6.24	M/s		
4	Dimensions of Stack	0.35	Mtr.		
5	Stack Area	0.0962	M ²		
6	Gas Volume	1905.29	Nm ³ /Hr		
7	Total Particulate Matter	19.15	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	07.56	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	1.24	mg/Nm ³	≤ 35	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Page 1 of 1

Verified By
Date: *06.02.26*
Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501
Website : www.neetalenvirolab.com, Mob. 8669699854 / 52
Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/01/ST/RE/844	Report Issue Date	23/01/2026		
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802				
Discipline	Chemical	Sample Description	Stack Material: FRP		
Group	Pollution & Environment.		Stack Height: 10.0 Mtr		
Sub Group	Stack Emission		Stack Type: Round		
Date of Sampling	15/01/2026	Sampling Location	(S15) Scrubber-1302 API-V		
Time of Sampling	10:00	Sampling duration	30 Min		
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring		
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026		
Name of Instrument	Stack Sampling Kit - 01	Date of Calibration	06/05/2025		
Calibration Certificate No.	SSEC/FF/1173	Due Date of Calibration	05/05/2026		
Results					
Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	352	°K	--	--
2	Differential Pressure	3.4	mm WG		
3	Velocity	6.57	M/s		
4	Dimensions of Stack	0.25	Mtr.		
5	Stack Area	0.0490	M ²		
6	Gas Volume	981.15	Nm ³ /Hr		
7	Total Particulate Matter	16.72	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	08.80	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	1.46	mg/Nm ³	≤ 35	OSHA 165 SG
Remark.					
<ul style="list-style-type: none">All above results are well within MPCB Limit.N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.					

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.


Reviewed By
(Ms. Kalyani Gore)




Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Page 1 of 1

Verified By
Date:  06.02.26
Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501
 Website : www.neetalenvirolab.com, Mob. 8669699854 / 52
 Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
 ISO 9001 : 2015
 ISO 14001 : 2015
 ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/01/ST/RE/845	Report Issue Date	23/01/2026
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: FRP
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	15/01/2026	Sampling Location	(S16) Scrubber-1303 API-V
Time of Sampling	10:37	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026
Name of Instrument	Stack Sampling Kit-107	Date of Calibration	08/10/2025
Calibration Certificate No.	SSEC/TH/303	Due Date of Calibration	07/10/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	354	°K	--	--
2	Differential Pressure	3.5	mm WG		
3	Velocity	6.68	M/s		
4	Dimensions of Stack	0.35	Mtr.		
5	Stack Area	0.0962	M ²		
6	Gas Volume	1947.45	Nm ³ /Hr		
7	Total Particulate Matter	18.34	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	10.62	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	1.04	mg/Nm ³	≤ 35	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
 Reviewed By
 (Ms. Kalyani Gore)



Abhishek
 Authorized Signatory
 (Mr. Abhishek Tope)

*****End of Report*****

Verified By
 Date: *Abhinav*
 06.02.26
 Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501
Website : www.neetalenvirolab.com, Mob. 8669699854 / 52
Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/01/ST/RE/846	Report Issue Date	23/01/2026
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: FRP
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	15/01/2026	Sampling Location	(S17) Scrubber-1304 API-V
Time of Sampling	11:10	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026
Name of Instrument	Stack Sampling Kit - 01	Date of Calibration	06/05/2025
Calibration Certificate No.	SSEC/FF/1173	Due Date of Calibration	05/05/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	349	°K	--	--
2	Differential Pressure	- 3.9	mm WG		
3	Velocity	7.01	M/s		
4	Dimensions of Stack	0.25	Mtr.		
5	Stack Area	0.0490	M ²		
6	Gas Volume	1055.86	Nm ³ /Hr		
7	Total Particulate Matter	12.47	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	09.36	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	0.93	mg/Nm ³	≤ 35	OSHA 165 SG

Remark.


- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.


Reviewed By
(Ms. Kalyani Gore)




Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Page 1 of 1

Verified By
Date: 
06.02.26
Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI.BK., TAL. KHED, DIST. PUNE - 410 501
Website : www.neetalenvirolab.com, Mob. 8669699854 / 52
Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/01/ST/RE/847	Report Issue Date	23/01/2026
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: FRP
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	15/01/2026	Sampling Location	(S18) Scrubber-1305 API-V
Time of Sampling	11:45	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026
Name of Instrument	Stack Sampling Kit-107	Date of Calibration	08/10/2025
Calibration Certificate No.	SSEC/TH/303	Due Date of Calibration	07/10/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	338	°K	--	--
2	Differential Pressure	3.5	mm WG		
3	Velocity	6.53	M/s		
4	Dimensions of Stack	0.25	Mtr.		
5	Stack Area	0.0490	M ²		
6	Gas Volume	1015.57	Nm ³ /Hr		
7	Total Particulate Matter	15.90	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	8.59	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	1.43	mg/Nm ³	≤ 35	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Page 1 of 1

Verified By
Date: *06.02.26*
Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501
Website : www.neetalenvirolab.com, Mob. 8669699854 / 52
Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/01/ST/RE/848	Report Issue Date	23/01/2026
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: FRP
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	15/01/2026	Sampling Location	(S19) Scrubber-1306 API-V
Time of Sampling	12:25	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026
Name of Instrument	Stack Sampling Kit - 01	Date of Calibration	06/05/2025
Calibration Certificate No.	SSEC/FF/1173	Due Date of Calibration	05/05/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	362	°K	--	--
2	Differential Pressure	3.7	mm WG		
3	Velocity	6.95	M/s		
4	Dimensions of Stack	0.25	Mtr.		
5	Stack Area	0.0490	M ²		
6	Gas Volume	1009.23	Nm ³ /Hr		
7	Total Particulate Matter	14.43	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	06.96	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	0.99	mg/Nm ³	≤ 35	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Page 1 of 1

Verified By
Date: *Abhishek*
86.02.26
Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501
Website : www.neetalenvirolab.com, Mob. 8669699854 / 52
Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/01/ST/RE/849	Report Issue Date	23/01/2026		
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802				
Discipline	Chemical	Sample Description	Stack Material: FRP		
Group	Pollution & Environment.		Stack Height: 10.0 Mtr		
Sub Group	Stack Emission		Stack Type: Round		
Date of Sampling	15/01/2026	Sampling Location	(S20) Scrubber-2301 STS Lab		
Time of Sampling	14:45	Sampling duration	30 Min		
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring		
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026		
Name of Instrument	Stack Sampling Kit-107	Date of Calibration	08/10/2025		
Calibration Certificate No.	SSEC/TH/303	Due Date of Calibration	07/10/2026		
Results					
Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	321	°K	--	--
2	Differential Pressure	3.4	mm WG		
3	Velocity	6.27	M/s		
4	Dimensions of Stack	0.25	Mtr.		
5	Stack Area	0.0490	M ²		
6	Gas Volume	1026.78	Nm ³ /Hr		
7	Total Particulate Matter	15.40	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	06.52	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	0.72	mg/Nm ³	≤ 35	OSHA 165 SG
Remark.					
<ul style="list-style-type: none">All above results are well within MPCB Limit.N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.					

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Page 1 of 1

Verified By
Date: *06.02.26*
Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/01/ST/RE/850	Report Issue Date	23/01/2026
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: FRP
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	14/01/2026	Sampling Location	(S21) Scrubber-1601 API-VI
Time of Sampling	17:05	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026
Name of Instrument	Stack Sampling Kit-107	Date of Calibration	08/10/2025
Calibration Certificate No.	SSEC/TH/303	Due Date of Calibration	07/10/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	335	°K	--	--
2	Differential Pressure	3.1	mm WG		
3	Velocity	6.12	M/s		
4	Dimensions of Stack	0.35	Mtr.		
5	Stack Area	0.0962	M ²		
6	Gas Volume	1885.39	Nm ³ /Hr		
7	Total Particulate Matter	18.64	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	07.28	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	1.43	mg/Nm ³	≤ 35	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Verified By
Date: *06.02.26*
Department EHS

Page 1 of 1

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501
 Website : www.neetalenvirolab.com, Mob. 8669699854 / 52
 Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
 ISO 9001 : 2015
 ISO 14001 : 2015
 ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/01/ST/RE/851	Report Issue Date	23/01/2026
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: FRP
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	14/01/2026	Sampling Location	(S22) Scrubber-1701 API-VII
Time of Sampling	12:50	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026
Name of Instrument	Stack Sampling Kit-107	Date of Calibration	08/10/2025
Calibration Certificate No.	SSEC/TH/303	Due Date of Calibration	07/10/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	343	°K	--	--
2	Differential Pressure	3.5	mm WG		
3	Velocity	6.58	M/s		
4	Dimensions of Stack	0.50	Mtr.		
5	Stack Area	0.1962	M ²		
6	Gas Volume	4037.84	Nm ³ /Hr		
7	Total Particulate Matter	14.12	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	6.59	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	0.85	mg/Nm ³	≤ 35	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
 Reviewed By
 (Ms. Kalyani Gore)



Abhishek
 Authorized Signatory
 (Mr. Abhishek Tope)

*****End of Report*****

Page 1 of 1

Verified By
 Date: *Abhishek*
 06.02.26
 Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501
Website : www.neetalenvirolab.com, Mob. 8669699854 / 52
Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/01/ST/RE/852	Report Issue Date	23/01/2026
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: FRP
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	14/01/2026	Sampling Location	(S23) Scrubber-1702 API-VII
Time of Sampling	13:27	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026
Name of Instrument	Stack Sampling Kit - 01	Date of Calibration	06/05/2025
Calibration Certificate No.	SSEC/FF/1173	Due Date of Calibration	05/05/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	348	°K	--	--
2	Differential Pressure	3.5	mm WG		
3	Velocity	6.63	M/s		
4	Dimensions of Stack	0.35	Mtr.		
5	Stack Area	0.0962	M ²		
6	Gas Volume	1966.20	Nm ³ /Hr		
7	Total Particulate Matter	22.15	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	09.86	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	1.23	mg/Nm ³	≤ 35	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Page 1 of 1

Verified By
Date: *Abhishek* 06.02.26
Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501
Website : www.neetalenvirolab.com, Mob. 8669699854 / 52
Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/01/ST/RE/853	Report Issue Date	23/01/2026
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: FRP
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission.		Stack Type: Round
Date of Sampling	14/01/2026	Sampling Location	(S24) Scrubber-1901 API-VII
Time of Sampling	14:00	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026
Name of Instrument	Stack Sampling Kit-107	Date of Calibration	08/10/2025
Calibration Certificate No.	SSEC/TH/303	Due Date of Calibration	07/10/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	340	°K	--	--
2	Differential Pressure	3.2	mm WG		
3	Velocity	6.26	M/s		
4	Dimensions of Stack	0.20	Mtr.		
5	Stack Area	0.0314	M ²		
6	Gas Volume	620.22	Nm ³ /Hr		
7	Total Particulate Matter	11.86	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	06.15	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	0.83	mg/Nm ³	≤ 35	OSHA 165 SG

Remark.


- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.


Reviewed By
(Ms. Kalyani Gore)




Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Page 1 of 1

Verified By
Date:  06.02.26
Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/01/ST/RE/854	Report Issue Date	23/01/2026
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: FRP
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	14/01/2026	Sampling Location	(S25) Scrubber-2001 API-VIII
Time of Sampling	11:05	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026
Name of Instrument	Stack Sampling Kit - 01	Date of Calibration	06/05/2025
Calibration Certificate No.	SSEC/FF/1173	Due Date of Calibration	05/05/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	354	°K	--	--
2	Differential Pressure	3.5	mm WG		
3	Velocity	6.68	M/s		
4	Dimensions of Stack	0.50	Mtr.		
5	Stack Area	0.1962	M ²		
6	Gas Volume	3971.83	Nm ³ /Hr		
7	Total Particulate Matter	12.80	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	6.90	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	1.14	mg/Nm ³	≤ 35	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Verified By
Date: *Abhishek*
06.02.26
Department EHS

Page 1 of 1

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/01/ST/RE/855	Report Issue Date	23/01/2026
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: FRP
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	14/01/2026	Sampling Location	(S26) Scrubber-2002 API-VIII
Time of Sampling	11:42	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026
Name of Instrument	Stack Sampling Kit-107	Date of Calibration	08/10/2025
Calibration Certificate No.	SSEC/TH/303	Due Date of Calibration	07/10/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	328	°K	--	--
2	Differential Pressure	3.3	mm WG		
3	Velocity	6.25	M/s		
4	Dimensions of Stack	0.35	Mtr.		
5	Stack Area	0.0962	M ²		
6	Gas Volume	1966.52	Nm ³ /Hr		
7	Total Particulate Matter	16.35	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	07.67	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	1.02	mg/Nm ³	≤ 35	OSHA 165 SG

Remark.


- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.


Reviewed By
(Ms. Kalyani Gore)




Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Page 1 of 1

Verified By
Date: 
06.02.26
Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501
Website : www.neetalenvirolab.com, Mob. 8669699854 / 52
Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/01/ST/RE/856	Report Issue Date	23/01/2026
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: FRP
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	14/01/2026	Sampling Location	(S27) Scrubber-2003 API-VIII
Time of Sampling	12:15	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026
Name of Instrument	Stack Sampling Kit - 01	Date of Calibration	06/05/2025
Calibration Certificate No.	SSEC/FF/1173	Due Date of Calibration	05/05/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	356	°K	--	--
2	Differential Pressure	3.7	mm WG		
3	Velocity	6.89	M/s		
4	Dimensions of Stack	0.35	Mtr.		
5	Stack Area	0.0962	M ²		
6	Gas Volume	1997.39	Nm ³ /Hr		
7	Total Particulate Matter	16.15	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	08.72	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	1.34	mg/Nm ³	≤ 35	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Page 1 of 1

Verified By
Date: *06.02.26*
Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI.BK., TAL. KHED, DIST. PUNE - 410 501
Website : www.neetalenvirolab.com, Mob. 8669699854 / 52
Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/01/ST/RE/857	Report Issue Date	23/01/2026
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: FRP
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	14/01/2026	Sampling Location	(S28) Scrubber-2201 API-X
Time of Sampling	14:40	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026
Name of Instrument	Stack Sampling Kit – 01	Date of Calibration	06/05/2025
Calibration Certificate No.	SSEC/FF/1173	Due Date of Calibration	05/05/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	346	°K	--	--
2	Differential Pressure	3.2	mm WG		
3	Velocity	6.32	M/s		
4	Dimensions of Stack	0.30	Mtr.		
5	Stack Area	0.07065	M ²		
6	Gas Volume	1384.43	Nm ³ /Hr		
7	Total Particulate Matter	11.72	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	09.16	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	1.20	mg/Nm ³	≤ 35	OSHA 165 SG

Remark.


- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.


Reviewed By
(Ms. Kalyani Gore)




Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Verified By
Date: 
06-02-26
Department EHS

Page 1 of 1

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501
 Website : www.neetalenvirolab.com, Mob. 8669699854 / 52
 Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
 ISO 9001 : 2015
 ISO 14001 : 2015
 ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/01/ST/RE/858	Report Issue Date	23/01/2026
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: FRP
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	15/01/2026	Sampling Location	(S29) Warehouse Scrubber 901
Time of Sampling	15:50	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026
Name of Instrument	Stack Sampling Kit-107	Date of Calibration	08/10/2025
Calibration Certificate No.	SSEC/TH/303	Due Date of Calibration	07/10/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	355	°K	--	--
2	Differential Pressure	3.5	mm WG		
3	Velocity	6.69	M/s		
4	Dimensions of Stack	0.35	Mtr.		
5	Stack Area	0.0962	M ²		
6	Gas Volume	1944.87	Nm ³ /Hr		
7	Total Particulate Matter	15.89	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	07.63	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	0.59	mg/Nm ³	≤ 35	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
 Reviewed By
 (Ms. Kalyani Gore)



Abhishek
 Authorized Signatory
 (Mr. Abhishek Tope)

*****End of Report*****

Verified By
 Date: *Abhishek*
 06.02.26
 Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501
 Website : www.neetalenvirolab.com, Mob. 8669699854 / 52
 Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
 ISO 9001 : 2015
 ISO 14001 : 2015
 ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/01/ST/RE/859	Report Issue Date	23/01/2026
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: FRP
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	15/01/2026	Sampling Location	(S30) Drum Shed Scrubber 902
Time of Sampling	16:40	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026
Name of Instrument	Stack Sampling Kit - 01	Date of Calibration	06/05/2025
Calibration Certificate No.	SSEC/FF/1173	Due Date of Calibration	05/05/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	343	°K	--	--
2	Differential Pressure	3.3	mm WG		
3	Velocity	6.39	M/s		
4	Dimensions of Stack	0.30	Mtr.		
5	Stack Area	0.07065	M ²		
6	Gas Volume	1412.01	Nm ³ /Hr		
7	Total Particulate Matter	12.34	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	07.67	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	0.79	mg/Nm ³	≤ 35	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
 Reviewed By
 (Ms. Kalyani Gore)



Abhishek
 Authorized Signatory
 (Mr. Abhishek Tope)

*****End of Report*****

Verified By
 Date: *06.02.26*
 Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501
Website : www.neetalenvirolab.com, Mob. 8669699854 / 52
Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/01/ST/RE/860	Report Issue Date	23/01/2026
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: FRP
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	14/01/2026	Sampling Location	(S31) Scrubber-2101 API -IX
Time of Sampling	13:35	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026
Name of Instrument	Stack Sampling Kit-107	Date of Calibration	08/10/2025
Calibration Certificate No.	SSEC/TH/303	Due Date of Calibration	07/10/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	332	°K	--	--
2	Differential Pressure	3.3	mm WG		
3	Velocity	6.28	M/s		
4	Dimensions of Stack	0.35	Mtr.		
5	Stack Area	0.0962	M ²		
6	Gas Volume	1952.16	Nm ³ /Hr		
7	Total Particulate Matter	17.75	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	09.43	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	0.92	mg/Nm ³	≤ 35	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.


Reviewed By
(Ms. Kalyani Gore)




Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Page 1 of 1

Verified By
Date: 
06.02.26
Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :

ISO 9001 : 2015

ISO 14001 : 2015

ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/10/ST/RE/563	Report Issue Date	17/10/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: FRP
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	10/10/2025	Sampling Location	(S7) API-I Scrubber-101
Time of Sampling	14:20	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025
Name of Instrument	Stack Sampling Kit - 01	Date of Calibration	06/05/2025
Calibration Certificate No.	SSEC/FF/1173	Due Date of Calibration	05/05/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	343	°K	--	--
2	Differential Pressure	4.8	mm WG		
3	Velocity	7.70	M/s		
4	Dimensions of Stack	0.50	Mtr.		
5	Stack Area	0.19625	M ²		
6	Gas Volume	4726.34	Nm ³ /Hr		
7	Total Particulate Matter	21.68	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	04.37	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	1.05	mg/Nm ³	≤ 35	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.


Reviewed By
(Ms. Kalyani Gore)




Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Verified By 
Date: 01.11.25
Department EHS

Page 1 of 1

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/10/ST/RE/564	Report Issue Date	17/10/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: FRP
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	10/10/2025	Sampling Location	(S8) API-II Scrubber-201
Time of Sampling	14:35	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025
Name of Instrument	Stack Sampling Kit-107	Date of Calibration	08/10/2025
Calibration Certificate No.	SSEC/TH/303	Due Date of Calibration	07/10/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	351	°K	--	--
2	Differential Pressure	5.5	mm WG		
3	Velocity	8.34	M/s		
4	Dimensions of Stack	0.30	Mtr.		
5	Stack Area	0.07065	M ²		
6	Gas Volume	1800.90	Nm ³ /Hr		
7	Total Particulate Matter	14.39	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	05.91	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	1.26	mg/Nm ³	≤ 35	OSHA 165 SG

Remark.


- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions


- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.


Reviewed By
(Ms. Kalyani Gore)




Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Verified By 
Date: 01.11.25
Department EHS

Page 1 of 1

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/10/ST/RE/565	Report Issue Date	17/10/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: FRP
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	10/10/2025	Sampling Location	(S9) API-III Scrubber- 301
Time of Sampling	15:10	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025
Name of Instrument	Stack Sampling Kit-107	Date of Calibration	08/10/2025
Calibration Certificate No.	SSEC/TH/303	Due Date of Calibration	07/10/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	349	°K	--	--
2	Differential Pressure	3.8	mm WG		
3	Velocity	6.91	M/s		
4	Dimensions of Stack	0.50	Mtr.		
5	Stack Area	0.19625	M ²		
6	Gas Volume	4168.51	Nm ³ /Hr		
7	Total Particulate Matter	17.58	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	05.02	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	1.18	mg/Nm ³	≤ 35	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Verified By *[Signature]*
Date: 01/11/25
Department EHS

Page 1 of 1

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :

ISO 9001 : 2015

ISO 14001 : 2015

ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/10/ST/RE/566	Report Issue Date	17/10/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: FRP
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	10/10/2025	Sampling Location	(S10) API-III Scrubber- 302
Time of Sampling	16:05	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025
Name of Instrument	Stack Sampling Kit – 01	Date of Calibration	06/05/2025
Calibration Certificate No.	SSEC/FF/1173	Due Date of Calibration	05/05/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	349	°K	--	--
2	Differential Pressure	3.5	mm WG		
3	Velocity	6.64	M/s		
4	Dimensions of Stack	0.30	Mtr.		
5	Stack Area	0.07065	M ²		
6	Gas Volume	1442.03	Nm ³ /Hr		
7	Total Particulate Matter	15.68	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	04.91	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	1.02	mg/Nm ³	≤ 35	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions


- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****



Page 1 of 1

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/10/ST/RE/567	Report Issue Date	17/10/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: FRP
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	10/10/2025	Sampling Location	(S11) API-III Scrubber- 303
Time of Sampling	15:45	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025
Name of Instrument	Stack Sampling Kit-107	Date of Calibration	08/10/2025
Calibration Certificate No.	SSEC/TH/303	Due Date of Calibration	07/10/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	353	°K	--	--
2	Differential Pressure	3.4	mm WG		
3	Velocity	6.58	M/s		
4	Dimensions of Stack	0.34	Mtr.		
5	Stack Area	0.09075	M ²		
6	Gas Volume	1814.75	Nm ³ /Hr		
7	Total Particulate Matter	15.40	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	06.12	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	0.95	mg/Nm ³	≤ 35	OSHA 165 SG

Remark.


- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions


- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.


Reviewed By
(Ms. Kalyani Gore)




Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Verified By 
Date: _____
Department EHS

Page 1 of 1

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501
 Website : www.neetalenvirolab.com, Mob. 8669699854 / 52
 Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
 ISO 9001 : 2015
 ISO 14001 : 2015
 ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/10/ST/RE/568	Report Issue Date	17/10/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: FRP
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	10/10/2025	Sampling Location	(S12) Scrubber-1401 API-IV
Time of Sampling	11:00	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025
Name of Instrument	Stack Sampling Kit-107	Date of Calibration	08/10/2025
Calibration Certificate No.	SSEC/TH/303	Due Date of Calibration	07/10/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	334	°K	--	--
2	Differential Pressure	3.5	mm WG		
3	Velocity	6.49	M/s		
4	Dimensions of Stack	0.34	Mtr.		
5	Stack Area	0.09075	M ²		
6	Gas Volume	1891.75	Nm ³ /Hr		
7	Total Particulate Matter	16.58	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	7.57	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	1.08	mg/Nm ³	≤ 35	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
 Reviewed By
 (Ms. Kalyani Gore)



Abhishek
 Authorized Signatory
 (Mr. Abhishek Tope)

*****End of Report*****

Verified By *B*
 Date: 01/11/25
 Department EHS

Page 1 of 1

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/10/ST/RE/569	Report Issue Date	17/10/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: FRP
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	10/10/2025	Sampling Location	(S13) Scrubber-1402 API-IV
Time of Sampling	11:25	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025
Name of Instrument	Stack Sampling Kit - 01	Date of Calibration	06/05/2025
Calibration Certificate No.	SSEC/FF/1173	Due Date of Calibration	05/05/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	339	°K	--	--
2	Differential Pressure	3.2	mm WG		
3	Velocity	6.25	M/s		
4	Dimensions of Stack	0.34	Mtr.		
5	Stack Area	0.09075	M ²		
6	Gas Volume	1794.92	Nm ³ /Hr		
7	Total Particulate Matter	18.85	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	7.22	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	1.25	mg/Nm ³	≤ 35	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.


Reviewed By
(Ms. Kalyani Gore)




Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Verified By

Date:

Department EHS


01/11/25

Page 1 of 1

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/10/ST/RE/570	Report Issue Date	17/10/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: FRP
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	10/10/2025	Sampling Location	(S14) Scrubber-1301 API-V
Time of Sampling	11:35	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025
Name of Instrument	Stack Sampling Kit-107	Date of Calibration	08/10/2025
Calibration Certificate No.	SSEC/TH/303	Due Date of Calibration	07/10/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	341	°K	--	--
2	Differential Pressure	3.5	mm WG		
3	Velocity	6.56	M/s		
4	Dimensions of Stack	0.35	Mtr.		
5	Stack Area	0.0962	M ²		
6	Gas Volume	1985.38	Nm ³ /Hr		
7	Total Particulate Matter	21.90	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	08.21	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	1.68	mg/Nm ³	≤ 35	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Verified By *[Signature]*
Date: 01/11/25
Department EHS

Page 1 of 1

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/10/ST/RE/571	Report Issue Date	17/10/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: FRP
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	10/10/2025	Sampling Location	(S15) Scrubber-1302 API-V
Time of Sampling	12:00	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025
Name of Instrument	Stack Sampling Kit - 01	Date of Calibration	06/05/2025
Calibration Certificate No.	SSEC/FF/1173	Due Date of Calibration	05/05/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	351	°K	--	--
2	Differential Pressure	3.8	mm WG		
3	Velocity	6.93	M/s		
4	Dimensions of Stack	0.25	Mtr.		
5	Stack Area	0.0490	M ²		
6	Gas Volume	1037.87	Nm ³ /Hr		
7	Total Particulate Matter	17.27	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	09.12	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	1.29	mg/Nm ³	≤ 35	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Verified By *B*
Date: *01/11/25*
Department EHS

Page 1 of 1

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/10/ST/RE/572	Report Issue Date	17/10/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: FRP
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	10/10/2025	Sampling Location	(S16) Scrubber-1303 API-V
Time of Sampling	12:10	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025
Name of Instrument	Stack Sampling Kit-107	Date of Calibration	08/10/2025
Calibration Certificate No.	SSEC/TH/303	Due Date of Calibration	07/10/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	358	°K	--	--
2	Differential Pressure	3.6	mm WG		
3	Velocity	6.82	M/s		
4	Dimensions of Stack	0.35	Mtr.		
5	Stack Area	0.0962	M ²		
6	Gas Volume	1966.05	Nm ³ /Hr		
7	Total Particulate Matter	19.67	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	11.40	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	0.89	mg/Nm ³	≤ 35	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Verified By *B*
Date: *01/11/25*
Department EHS

Page 1 of 1

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :

ISO 9001 : 2015

ISO 14001 : 2015

ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/10/ST/RE/573	Report Issue Date	17/10/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: FRP
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	10/10/2025	Sampling Location	(S17) Scrubber-1304 API-V
Time of Sampling	12:35	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025
Name of Instrument	Stack Sampling Kit - 01	Date of Calibration	06/05/2025
Calibration Certificate No.	SSEC/FF/1173	Due Date of Calibration	05/05/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	351	°K	--	--
2	Differential Pressure	3.8	mm WG		
3	Velocity	6.93	M/s		
4	Dimensions of Stack	0.25	Mtr.		
5	Stack Area	0.0490	M ²		
6	Gas Volume	1037.87	Nm ³ /Hr		
7	Total Particulate Matter	14.82	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	10.15	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	0.88	mg/Nm ³	≤ 35	OSHA 165 SG

Remark.


- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.


Reviewed By
(Ms. Kalyani Gore)




Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Verified By

Date:

Department EHS



Page 1 of 1

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :

ISO 9001 : 2015

ISO 14001 : 2015

ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/10/ST/RE/574	Report Issue Date	17/10/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: FRP
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	10/10/2025	Sampling Location	(S18) Scrubber-1305 API-V
Time of Sampling	12:45	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025
Name of Instrument	Stack Sampling Kit-107	Date of Calibration	08/10/2025
Calibration Certificate No.	SSEC/TH/303	Due Date of Calibration	07/10/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	333	°K	--	--
2	Differential Pressure	3.4	mm WG		
3	Velocity	6.39	M/s		
4	Dimensions of Stack	0.25	Mtr.		
5	Stack Area	0.0490	M ²		
6	Gas Volume	1008.72	Nm ³ /Hr		
7	Total Particulate Matter	16.63	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	8.40	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	1.37	mg/Nm ³	≤ 35	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Verified By
Date: *01/11/25*
Department EHS

Page 1 of 1

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501
Website : www.neetalenvirolab.com, Mob. 8669699854 / 52
Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/10/ST/RE/575	Report Issue Date	17/10/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: FRP
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	10/10/2025	Sampling Location	(S19) Scrubber-1306 API-V
Time of Sampling	13:10	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025
Name of Instrument	Stack Sampling Kit – 01	Date of Calibration	06/05/2025
Calibration Certificate No.	SSEC/FF/1173	Due Date of Calibration	05/05/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	356	°K	--	--
2	Differential Pressure	3.4	mm WG		
3	Velocity	6.61	M/s		
4	Dimensions of Stack	0.25	Mtr.		
5	Stack Area	0.0490	M ²		
6	Gas Volume	976.04	Nm ³ /Hr		
7	Total Particulate Matter	15.27	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	07.25	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	0.85	mg/Nm ³	≤ 35	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Verified By *B*
Date: 01.11.25
Department EHS

Page 1 of 1

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/10/ST/RE/576	Report Issue Date	17/10/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: FRP
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	10/10/2025	Sampling Location	(S20) Scrubber-2301 STS Lab
Time of Sampling	13:20	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025
Name of Instrument	Stack Sampling Kit-107	Date of Calibration	08/10/2025
Calibration Certificate No.	SSEC/TH/303	Due Date of Calibration	07/10/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	311	°K	--	--
2	Differential Pressure	3.2	mm WG		
3	Velocity	5.99	M/s		
4	Dimensions of Stack	0.25	Mtr.		
5	Stack Area	0.0490	M ²		
6	Gas Volume	1012.47	Nm ³ /Hr		
7	Total Particulate Matter	16.29	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	07.72	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	0.76	mg/Nm ³	≤ 35	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
 Reviewed By
 (Ms. Kalyani Gore)



Abhishek
 Authorized Signatory
 (Mr. Abhishek Tope)

*****End of Report*****

Verified By *[Signature]*
 Date: 01.11.25
 Department: []

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501
 Website : www.neetalenvirolab.com, Mob. 8669699854 / 52
 Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
 ISO 9001 : 2015
 ISO 14001 : 2015
 ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/10/ST/RE/577	Report Issue Date	17/10/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: FRP
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	09/10/2025	Sampling Location	(S21) Scrubber-1601 API-VI
Time of Sampling	12:50	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025
Name of Instrument	Stack Sampling Kit-107	Date of Calibration	08/10/2025
Calibration Certificate No.	SSEC/TH/303	Due Date of Calibration	07/10/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	339	°K	--	--
2	Differential Pressure	3.2	mm WG		
3	Velocity	6.25	M/s		
4	Dimensions of Stack	0.35	Mtr.		
5	Stack Area	0.0962	M ²		
6	Gas Volume	1902.72	Nm ³ /Hr		
7	Total Particulate Matter	19.80	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	07.90	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	1.19	mg/Nm ³	≤ 35	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
 Reviewed By
 (Ms. Kalyani Gore)



Abhishek
 Authorized Signatory
 (Mr. Abhishek Tope)

*****End of Report*****

Verified By *[Signature]*
 Date: 21/11/25
 Instrument: EMS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501
Website : www.neetalenvirolab.com, Mob. 8669699854 / 52
Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/10/ST/RE/578	Report Issue Date	17/10/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: FRP
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	10/10/2025	Sampling Location	(S22) Scrubber-1701 API-VII
Time of Sampling	16:55	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025
Name of Instrument	Stack Sampling Kit-107	Date of Calibration	08/10/2025
Calibration Certificate No.	SSEC/TH/303	Due Date of Calibration	07/10/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	336	°K	--	--
2	Differential Pressure	3.4	mm WG		
3	Velocity	6.42	M/s		
4	Dimensions of Stack	0.50	Mtr.		
5	Stack Area	0.1962	M ²		
6	Gas Volume	4021.74	Nm ³ /Hr		
7	Total Particulate Matter	15.91	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	6.28	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	1.05	mg/Nm ³	≤ 35	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.



Reviewed By
(Ms. Kalyani Gore)




Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Page 1 of 1

Verified By	
Date:	21/11/25
Department EHS	

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501
Website : www.neetalenvirolab.com, Mob. 8669699854 / 52
Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/10/ST/RE/579	Report Issue Date	17/10/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: FRP
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	10/10/2025	Sampling Location	(S23) Scrubber-1702 API-VII
Time of Sampling	17:15	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025
Name of Instrument	Stack Sampling Kit - 01	Date of Calibration	06/05/2025
Calibration Certificate No.	SSEC/FF/1173	Due Date of Calibration	05/05/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	354	°K	--	--
2	Differential Pressure	3.5	mm WG		
3	Velocity	6.68	M/s		
4	Dimensions of Stack	0.35	Mtr.		
5	Stack Area	0.0962	M ²		
6	Gas Volume	1947.45	Nm ³ /Hr		
7	Total Particulate Matter	23.68	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	09.49	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	1.12	mg/Nm ³	≤ 35	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Page 1 of 1

Verified By *B*
Date: *01.11.25*
Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501
 Website : www.neetalenvirolab.com, Mob. 8669699854 / 52
 Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
 ISO 9001 : 2015
 ISO 14001 : 2015
 ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/10/ST/RE/580	Report Issue Date	17/10/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: FRP
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	10/10/2025	Sampling Location	(S24) Scrubber-1901 API-VII
Time of Sampling	17:30	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025
Name of Instrument	Stack Sampling Kit-107	Date of Calibration	08/10/2025
Calibration Certificate No.	SSEC/TH/303	Due Date of Calibration	07/10/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	334	°K	--	--
2	Differential Pressure	3.1	mm WG		
3	Velocity	6.11	M/s		
4	Dimensions of Stack	0.20	Mtr.		
5	Stack Area	0.0314	M ²		
6	Gas Volume	616.23	Nm ³ /Hr		
7	Total Particulate Matter	12.96	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	07.21	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	0.76	mg/Nm ³	≤ 35	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N,S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
 Reviewed By
 (Ms. Kalyani Gore)



Abhishek
 Authorized Signatory
 (Mr. Abhishek Tope)

*****End of Report*****

Page 1 of 1

Verified By *B*
 Date: 01/11/25
 Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :

ISO 9001 : 2015

ISO 14001 : 2015

ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/10/ST/RE/581	Report Issue Date	17/10/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: FRP
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	09/10/2025	Sampling Location	(S25) Scrubber-2001 API-VIII
Time of Sampling	15:15	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025
Name of Instrument	Stack Sampling Kit - 01	Date of Calibration	06/05/2025
Calibration Certificate No.	SSEC/FF/1173	Due Date of Calibration	05/05/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	358	°K	--	--
2	Differential Pressure	3.6	mm WG		
3	Velocity	6.82	M/s		
4	Dimensions of Stack	0.50	Mtr.		
5	Stack Area	0.1962	M ²		
6	Gas Volume	4009.77	Nm ³ /Hr		
7	Total Particulate Matter	13.93	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	6.14	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	0.90	mg/Nm ³	≤ 35	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Verified By *[Signature]*
Date: 21/11/25
Department EHS

Page 1 of 1

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :

ISO 9001 : 2015

ISO 14001 : 2015

ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/10/ST/RE/582	Report Issue Date	17/10/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: FRP
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	09/10/2025	Sampling Location	(S26) Scrubber-2002 API-VIII
Time of Sampling	15:30	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025
Name of Instrument	Stack Sampling Kit-107	Date of Calibration	08/10/2025
Calibration Certificate No.	SSEC/TH/303	Due Date of Calibration	07/10/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	322	°K	--	--
2	Differential Pressure	3.4	mm WG		
3	Velocity	6.28	M/s		
4	Dimensions of Stack	0.35	Mtr.		
5	Stack Area	0.0962	M ²		
6	Gas Volume	2012.79	Nm ³ /Hr		
7	Total Particulate Matter	17.36	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	08.01	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	1.16	mg/Nm ³	≤ 35	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions


- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.


Reviewed By
(Ms. Kalyani Gore)




Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Verified By 
Date: 20/11/25
Department EHS

Page 1 of 1

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501
 Website : www.neetalenvirolab.com, Mob. 8669699854 / 52
 Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
 ISO 9001 : 2015
 ISO 14001 : 2015
 ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/10/ST/RE/583	Report Issue Date	17/10/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: FRP
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	09/10/2025	Sampling Location	(S27) Scrubber-2003 API-VIII
Time of Sampling	15:50	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025
Name of Instrument	Stack Sampling Kit - 01	Date of Calibration	06/05/2025
Calibration Certificate No.	SSEC/FF/1173	Due Date of Calibration	05/05/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	351	°K	--	--
2	Differential Pressure	3.6	mm WG		
3	Velocity	6.75	M/s		
4	Dimensions of Stack	0.35	Mtr.		
5	Stack Area	0.0962	M ²		
6	Gas Volume	1984.68	Nm ³ /Hr		
7	Total Particulate Matter	17.50	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	08.90	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	1.14	mg/Nm ³	≤ 35	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL - Below Detection Limit & ND - Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
 Reviewed By
 (Ms. Kalyani Gore)



Abhishek
 Authorized Signatory
 (Mr. Abhishek Tope)

*****End of Report*****

Verified By *B*
 Date: *01/11/25*
 Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501
Website : www.neetalenvirolab.com, Mob. 8669699854 / 52
Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/10/ST/RE/584	Report Issue Date	17/10/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: FRP
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	10/10/2025	Sampling Location	(S28) Scrubber-2201 API-X
Time of Sampling	13:45	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025
Name of Instrument	Stack Sampling Kit - 01	Date of Calibration	06/05/2025
Calibration Certificate No.	SSEC/FF/1173	Due Date of Calibration	05/05/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	351	°K	--	--
2	Differential Pressure	3.5	mm WG		
3	Velocity	6.66	M/s		
4	Dimensions of Stack	0.30	Mtr.		
5	Stack Area	0.07065	M ²		
6	Gas Volume	1438.13	Nm ³ /Hr		
7	Total Particulate Matter	12.46	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	08.68	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	0.87	mg/Nm ³	≤ 35	OSHA 165 SG

Remark.


- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions


- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.


Reviewed By
(Ms. Kalyani Gore)




Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Verified By
Date: 
Department EHS

Page 1 of 1

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501
Website : www.neetalenvirolab.com, Mob. 8669699854 / 52
Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/10/ST/RE/585	Report Issue Date	17/10/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: FRP
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	09/10/2025	Sampling Location	(S29) Warehouse Scrubber 901
Time of Sampling	16:40	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025
Name of Instrument	Stack Sampling Kit-107	Date of Calibration	08/10/2025
Calibration Certificate No.	SSEC/TH/303	Due Date of Calibration	07/10/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	351	°K	--	--
2	Differential Pressure	3.7	mm WG		
3	Velocity	6.84	M/s		
4	Dimensions of Stack	0.35	Mtr.		
5	Stack Area	0.0962	M ²		
6	Gas Volume	2011.14	Nm ³ /Hr		
7	Total Particulate Matter	16.40	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	07.72	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	0.37	mg/Nm ³	≤ 35	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions


- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.


Reviewed By
(Ms. Kalyani Gore)




Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Verified By
Date: 
Department EHS

Page 1 of 1

TEST REPORT (Stack Emission)			
Report No.	NLES/25-26/10/ST/RE/586	Report Issue Date	17/10/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: FRP
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	09/10/2025	Sampling Location	(S30) Drum Shed Scrubber 902
Time of Sampling	17:00	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025
Name of Instrument	Stack Sampling Kit - 01	Date of Calibration	06/05/2025
Calibration Certificate No.	SSEC/FF/1173	Due Date of Calibration	05/05/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	350	°K	--	--
2	Differential Pressure	3.4	mm WG		
3	Velocity	6.54	M/s		
4	Dimensions of Stack	0.30	Mtr.		
5	Stack Area	0.07065	M ²		
6	Gas Volume	1416.25	Nm ³ /Hr		
7	Total Particulate Matter	13.59	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	07.63	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	0.82	mg/Nm ³	≤ 35	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
 Reviewed By
 (Ms. Kalyani Gore)



Abhishek
 Authorized Signatory
 (Mr. Abhishek Tope)

*****End of Report*****

Verified By *B*
 Date: *01/11/25*
 Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/10/ST/RE/587	Report Issue Date	17/10/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: FRP
Group	Pollution & Environment.		Stack Height: 10.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	09/10/2025	Sampling Location	(S31) Scrubber-2101 API -IX
Time of Sampling	17:15	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025
Name of Instrument	Stack Sampling Kit-107	Date of Calibration	08/10/2025
Calibration Certificate No.	SSEC/TH/303	Due Date of Calibration	07/10/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	326	°K	--	--
2	Differential Pressure	3.4	mm WG		
3	Velocity	6.32	M/s		
4	Dimensions of Stack	0.35	Mtr.		
5	Stack Area	0.0962	M ²		
6	Gas Volume	2000.75	Nm ³ /Hr		
7	Total Particulate Matter	16.56	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Oxides of Nitrogen (NO _x)	08.47	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
9	Acid Mist	0.98	mg/Nm ³	≤ 35	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions


- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.


Reviewed By
(Ms. Kalyani Gore)




Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Verified By 
Date: 01/11/25
Department EHS

Page 1 of 1

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/01/ST/RE/818	Report Issue Date	23/01/2026		
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802				
Discipline	Chemical	Sample Description	Stack Material: MS		
Group	Pollution & Environment.		Stack Height: 30.0 Mtr		
Sub Group	Stack Emission		Stack Type: Round		
Date of Sampling	14/01/2026	Sampling Location	(S1) Briquette Boiler		
Time of Sampling	12:10	Sampling duration	30 Min		
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring		
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026		
Name of Instrument	Stack Sampling Kit – 01	Date of Calibration	06/05/2025		
Calibration Certificate No.	SSEC/FF/1173	Due Date of Calibration	05/05/2026		
Results					
Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	443	°K	--	--
2	Differential Pressure	4.8	mm WG		
3	Velocity	8.76	M/s		
4	Dimensions of Stack	0.70	Mtr.		
5	Stack Area	0.3846	M ²		
6	Gas Volume	8158.84	Nm ³ /Hr		
7	Total Particulate Matter	56.18	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Carbon Monoxide	0.91	mg/Nm ³	N.S.	IS 13270:1992 RA 2014
9	Carbon Dioxide	468	PPM	N.S.	IS 13270:1992 RA 2014
10	Sulphur Dioxide (SO ₂)	BDL	mg/Nm ³	N.S.	IS 11255 (Part 2)
11	Sulphur Dioxide (SO ₂)	BDL	Kg/day	N.S.	IS 11255 (Part 2)
12	Oxides of Nitrogen (NO _x)	BDL	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
Remark.					
<ul style="list-style-type: none"> All above results are well within MPCB Limit. N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected. 					

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Verified By
Date: *06.02.26*
Department EHS

Page 1 of 1

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/10/ST/RE/545	Report Issue Date	17/10/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: MS
Group	Pollution & Environment.		Stack Height: 30.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	09/10/2025	Sampling Location	(S1) Briquette Boiler
Time of Sampling	11:20	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025
Name of Instrument	Stack Sampling Kit - 01	Date of Calibration	06/05/2025
Calibration Certificate No.	SSEC/FF/1173	Due Date of Calibration	05/05/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	438	°K	--	--
2	Differential Pressure	4.9	mm WG		
3	Velocity	8.79	M/s		
4	Dimensions of Stack	0.70	Mtr.		
5	Stack Area	0.3846	M ²		
6	Gas Volume	8280.24	Nm ³ /Hr		
7	Total Particulate Matter	57.14	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Carbon Monoxide	0.89	mg/Nm ³	N.S.	IS 13270:1992 RA 2014
9	Carbon Dioxide	435	PPM	N.S.	IS 13270:1992 RA 2014
10	Sulphur Dioxide (SO ₂)	BDL	mg/Nm ³	N.S.	IS 11255 (Part 2)
11	Sulphur Dioxide (SO ₂)	BDL	Kg/day	N.S.	IS 11255 (Part 2)
12	Oxides of Nitrogen (NO _x)	BDL	mg/Nm ³	N.S.	IS11255 (PART 7): 2005

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL - Below Detection Limit & ND - Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Verified By
Date: 01.11.25
Department EHS

Page 1 of 1

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/01/ST/RE/819	Report Issue Date	23/01/2026
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: MS
Group	Pollution & Environment.		Stack Height: 30.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	14/01/2026	Sampling Location	(S1) LSHS Boiler
Time of Sampling	12:45	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026
Name of Instrument	Stack Sampling Kit - 01	Date of Calibration	06/05/2025
Calibration Certificate No.	SSEC/FF/1173	Due Date of Calibration	05/05/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	472	°K	--	--
2	Differential Pressure	4.9	mm WG		
3	Velocity	9.13	M/s		
4	Dimensions of Stack	0.70	Mtr.		
5	Stack Area	0.3846	M ²		
6	Gas Volume	7980.99	Nm ³ /Hr		
7	Total Particulate Matter	62.16	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Carbon Monoxide	0.79	mg/Nm ³	N.S.	IS 13270:1992 RA 2014
9	Carbon Dioxide	395	PPM	N.S.	IS 13270:1992 RA 2014
10	Sulphur Dioxide (SO ₂)	38.12	mg/Nm ³	N.S.	IS 11255 (Part 2)
11	Sulphur Dioxide (SO ₂)	7.30	Kg/day	≤ 240	IS 11255 (Part 2)
12	Oxides of Nitrogen (NO _x)	BDL	mg/Nm ³	≤ 50	IS11255 (PART 7): 2005

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Verified By
Date: *06.02.26*
Department EHS

Page 1 of 1

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501
Website : www.neetalenvirolab.com, Mob. 8669699854 / 52
Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/10/ST/RE/546	Report Issue Date	17/10/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: MS
Group	Pollution & Environment.		Stack Height: 30.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	09/10/2025	Sampling Location	(S1) LSHS Boiler
Time of Sampling	11:55	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025
Name of Instrument	Stack Sampling Kit - 01	Date of Calibration	06/05/2025
Calibration Certificate No.	SSEC/FF/1173	Due Date of Calibration	05/05/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	476	°K		
2	Differential Pressure	4.7	mm WG		
3	Velocity	8.98	M/s		
4	Dimensions of Stack	0.70	Mtr.		
5	Stack Area	0.3846	M ²		
6	Gas Volume	7783.90	Nm ³ /Hr		
7	Total Particulate Matter	64.35	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Carbon Monoxide	0.81	mg/Nm ³	N.S.	IS 13270:1992 RA 2014
9	Carbon Dioxide	422	PPM	N.S.	IS 13270:1992 RA 2014
10	Sulphur Dioxide (SO ₂)	37.69	mg/Nm ³	N.S.	IS 11255 (Part 2)
11	Sulphur Dioxide (SO ₂)	7.04	Kg/day	≤ 240	IS 11255 (Part 2)
12	Oxides of Nitrogen (NO _x)	BDL	mg/Nm ³	≤ 50	IS11255 (PART 7): 2005

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified, BDL – Below Detection Limit & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Verified By *[Signature]*
Date: 01.11.25
Department EHS

Page 1 of 1

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/01/ST/RE/820	Report Issue Date	23/01/2026
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: MS
Group	Pollution & Environment.		Stack Height: 6.5 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	14/01/2026	Sampling Location	(S3) D. G. Set-5 (1010 KVA)
Time of Sampling	15:10	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026
Name of Instrument	Stack Sampling Kit - 01	Date of Calibration	06/05/2025
Calibration Certificate No.	SSEC/FF/1173	Due Date of Calibration	05/05/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	569	°K	--	--
2	Differential Pressure	6.6	mm WG		
3	Velocity	11.64	M/s		
4	Dimensions of Stack	0.25	Mtr.		
5	Stack Area	0.0490	M ²		
6	Gas Volume	1075.36	Nm ³ /Hr		
7	Total Particulate Matter	69.15	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Sulphur Dioxide (SO ₂)	50.40	mg/Nm ³	N.S.	IS 11255 (Part 2)
9	Sulphur Dioxide (SO ₂)	1.30	Kg/day	≤ 768	IS 11255 (Part 2)
10	Oxides of Nitrogen (NO _x)	24.5	mg/Nm ³	N.S.	IS11255 (PART 7): 2005

Remark.


- All above results are well within MPCB Limit.
- N.S - Not Specified & ND - Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.


Reviewed By
(Ms. Kalyani Gore)




Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Page 1 of 1

Verified By
Date: 
06.02.26
Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :

ISO 9001 : 2015

ISO 14001 : 2015

ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/01/ST/RE/821	Report Issue Date	23/01/2026
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: MS
Group	Pollution & Environment.		Stack Height: 6.5 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	14/01/2026	Sampling Location	(S4) D. G. Set-6 (1010 KVA)
Time of Sampling	15:15	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026
Name of Instrument	Stack Sampling Kit-107	Date of Calibration	08/10/2025
Calibration Certificate No.	SSEC/TH/303	Due Date of Calibration	07/10/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	627	°K	--	--
2	Differential Pressure	7.4	mm WG		
3	Velocity	12.93	M/s		
4	Dimensions of Stack	0.25	Mtr.		
5	Stack Area	0.0490	M ²		
6	Gas Volume	1084.04	Nm ³ /Hr		
7	Total Particulate Matter	71.16	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Sulphur Dioxide (SO ₂)	54.85	mg/Nm ³	N.S.	IS 11255 (Part 2)
9	Sulphur Dioxide (SO ₂)	1.42	Kg/day	≤ 768	IS 11255 (Part 2)
10	Oxides of Nitrogen (NO _x)	22.8	mg/Nm ³	N.S.	IS11255 (PART 7): 2005

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Page 1 of 1

Verified By
Date: *Abhishek*
06.02.26
Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :

ISO 9001 : 2015

ISO 14001 : 2015

ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/01/ST/RE/822	Report Issue Date	23/01/2026
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: MS
Group	Pollution & Environment.		Stack Height: 30.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	14/01/2026	Sampling Location	(S5) D. G. Set-7 (1500 KVA)
Time of Sampling	15:45	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026
Name of Instrument	Stack Sampling Kit - 01	Date of Calibration	06/05/2025
Calibration Certificate No.	SSEC/FF/1173	Due Date of Calibration	05/05/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	726	°K	--	--
2	Differential Pressure	8.1	mm WG		
3	Velocity	14.56	M/s		
4	Dimensions of Stack	0.35	Mtr.		
5	Stack Area	0.0961	M ²		
6	Gas Volume	2067.60	Nm ³ /Hr		
7	Total Particulate Matter	75.51	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Sulphur Dioxide (SO ₂)	59.04	mg/Nm ³	N.S.	IS 11255 (Part 2)
9	Sulphur Dioxide (SO ₂)	2.93	Kg/day	≤ 1536	IS 11255 (Part 2)
10	Oxides of Nitrogen (NO _x)	37.2	mg/Nm ³	N.S.	IS11255 (PART 7): 2005

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified & ND - Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Page 1 of 1

Verified By
Date: *06.02.26*
Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/01/ST/RE/823	Report Issue Date	23/01/2026		
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802				
Discipline	Chemical	Sample Description	Stack Material: MS		
Group	Pollution & Environment.		Stack Height: 30.0 Mtr		
Sub Group	Stack Emission		Stack Type: Round		
Date of Sampling	14/01/2026	Sampling Location	(S6) D. G. Set-8 (1500 KVA)		
Time of Sampling	15:48	Sampling duration	30 Min		
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring		
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026		
Name of Instrument	Stack Sampling Kit-107	Date of Calibration	08/10/2025		
Calibration Certificate No.	SSEC/TH/303	Due Date of Calibration	07/10/2026		
Results					
Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	713	°K	--	--
2	Differential Pressure	8.4	mm WG		
3	Velocity	14.69	M/s		
4	Dimensions of Stack	0.35	Mtr.		
5	Stack Area	0.0961	M ²		
6	Gas Volume	2124.10	Nm ³ /Hr		
7	Total Particulate Matter	73.75	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Sulphur Dioxide (SO ₂)	62.16	mg/Nm ³	N.S.	IS 11255 (Part 2)
9	Sulphur Dioxide (SO ₂)	3.17	Kg/day	≤ 1536	IS 11255 (Part 2)
10	Oxides of Nitrogen (NO _x)	28.2	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
Remark.					
<ul style="list-style-type: none">All above results are well within MPCB Limit.N.S - Not Specified & ND – Not Detected.					

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Page 1 of 1

Verified By
Date: *Abhishek*
06.02.26
Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/01/ST/RE/863	Report Issue Date	23/01/2026
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: MS
Group	Pollution & Environment.		Stack Height: 2.5 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	15/01/2026	Sampling Location	(S61) Fire Engine DG Pump- 100 KVA
Time of Sampling	16:02	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026
Name of Instrument	Stack Sampling Kit-107	Date of Calibration	08/10/2025
Calibration Certificate No.	SSEC/TH/303	Due Date of Calibration	07/10/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	372	°K	--	--
2	Differential Pressure	3.8	mm WG		
3	Velocity	7.13	M/s		
4	Dimensions of Stack	0.10	Mtr.		
5	Stack Area	0.00785	M ²		
6	Gas Volume	161.41	Nm ³ /Hr		
7	Total Particulate Matter	61.43	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Sulphur Dioxide (SO ₂)	36.15	mg/Nm ³	N.S.	IS 11255 (Part 2)
9	Sulphur Dioxide (SO ₂)	0.14	Kg/day	≤ 7.2	IS 11255 (Part 2)
10	Oxides of Nitrogen (NO _x)	11.9	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
11	Acid Mist	ND	mg/Nm ³	N.S.	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Page 1 of 1

Verified By
Date: *Abhishek*
06.02.26
Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/10/ST/RE/547	Report Issue Date	17/10/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: MS
Group	Pollution & Environment.		Stack Height: 6.5 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	09/10/2025	Sampling Location	(S3) D. G. Set-5 (1010 KVA)
Time of Sampling	14:05	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025
Name of Instrument	Stack Sampling Kit - 01	Date of Calibration	06/05/2025
Calibration Certificate No.	SSEC/FF/1173	Due Date of Calibration	05/05/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	576	°K	--	--
2	Differential Pressure	6.4	mm WG		
3	Velocity	11.53	M/s		
4	Dimensions of Stack	0.25	Mtr.		
5	Stack Area	0.0490	M ²		
6	Gas Volume	1052.26	Nm ³ /Hr		
7	Total Particulate Matter	71.02	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Sulphur Dioxide (SO ₂)	52.89	mg/Nm ³	N.S.	IS 11255 (Part 2)
9	Sulphur Dioxide (SO ₂)	1.34	Kg/day	≤ 768	IS 11255 (Part 2)
10	Oxides of Nitrogen (NO _x)	26.9	mg/Nm ³	N.S.	IS11255 (PART 7): 2005

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Verified By *[Signature]*
Date: 01/11/25
Department EHS

Page 1 of 1

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/10/ST/RE/548	Report Issue Date	17/10/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: MS
Group	Pollution & Environment.		Stack Height: 6.5 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	09/10/2025	Sampling Location	(S4) D. G. Set-6 (1010 KVA)
Time of Sampling	14:22	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025
Name of Instrument	Stack Sampling Kit-107	Date of Calibration	08/10/2025
Calibration Certificate No.	SSEC/TH/303	Due Date of Calibration	07/10/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	622	°K	--	--
2	Differential Pressure	7.3	mm WG		
3	Velocity	12.79	M/s		
4	Dimensions of Stack	0.25	Mtr.		
5	Stack Area	0.0490	M ²		
6	Gas Volume	1080.92	Nm ³ /Hr		
7	Total Particulate Matter	72.90	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Sulphur Dioxide (SO ₂)	59.12	mg/Nm ³	N.S.	IS 11255 (Part 2)
9	Sulphur Dioxide (SO ₂)	1.53	Kg/day	≤ 768	IS 11255 (Part 2)
10	Oxides of Nitrogen (NO _x)	27.1	mg/Nm ³	N.S.	IS11255 (PART 7): 2005

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
 Reviewed By
 (Ms. Kalyani Gore)



Abhishek
 Authorized Signatory
 (Mr. Abhishek Tope)

*****End of Report*****

Verified By *[Signature]*
 Date: *01/11/25*
 Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :

ISO 9001 : 2015

ISO 14001 : 2015

ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/10/ST/RE/549	Report Issue Date	17/10/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: MS
Group	Pollution & Environment.		Stack Height: 30.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	09/10/2025	Sampling Location	(S5) D. G. Set-7 (1500 KVA)
Time of Sampling	14:40	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025
Name of Instrument	Stack Sampling Kit - 01	Date of Calibration	06/05/2025
Calibration Certificate No.	SSEC/FF/1173	Due Date of Calibration	05/05/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	719	°K	--	--
2	Differential Pressure	8.2	mm WG		
3	Velocity	14.58	M/s		
4	Dimensions of Stack	0.35	Mtr.		
5	Stack Area	0.0961	M ²		
6	Gas Volume	2090.60	Nm ³ /Hr		
7	Total Particulate Matter	76.15	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Sulphur Dioxide (SO ₂)	60.85	mg/Nm ³	N.S.	IS 11255 (Part 2)
9	Sulphur Dioxide (SO ₂)	3.05	Kg/day	≤ 1536	IS 11255 (Part 2)
10	Oxides of Nitrogen (NO _x)	36.8	mg/Nm ³	N.S.	IS11255 (PART 7): 2005

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified & ND - Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By

(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Page 1 of 1

Verified By	<i>[Signature]</i>
Date:	07/11/25
Department	EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501
Website : www.neetalenvirolab.com, Mob. 8669699854 / 52
Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/10/ST/RE/550	Report Issue Date	17/10/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: MS
Group	Pollution & Environment.		Stack Height: 30.0 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	09/10/2025	Sampling Location	(S6) D. G. Set-8 (1500 KVA)
Time of Sampling	14:56	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025
Name of Instrument	Stack Sampling Kit-107	Date of Calibration	08/10/2025
Calibration Certificate No.	SSEC/TH/303	Due Date of Calibration	07/10/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	709	°K	--	--
2	Differential Pressure	8.1	mm WG		
3	Velocity	14.39	M/s		
4	Dimensions of Stack	0.35	Mtr.		
5	Stack Area	0.0961	M ²		
6	Gas Volume	2092.46	Nm ³ /Hr		
7	Total Particulate Matter	74.69	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Sulphur Dioxide (SO ₂)	61.90	mg/Nm ³	N.S.	IS 11255 (Part 2)
9	Sulphur Dioxide (SO ₂)	3.11	Kg/day	≤ 1536	IS 11255 (Part 2)
10	Oxides of Nitrogen (NO _x)	32.6	mg/Nm ³	N.S.	IS11255 (PART 7): 2005

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified & ND – Not Detected.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Verified By *B*
Date: *01.11.25*
Department EHS

Page 1 of 1

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501
 Website : www.neetalenvirolab.com, Mob. 8669699854 / 52
 Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
 ISO 9001 : 2015
 ISO 14001 : 2015
 ISO 45001 : 2018

TEST REPORT (Stack Emission)

Report No.	NLES/25-26/10/ST/RE/590	Report Issue Date	17/10/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Sample Description	Stack Material: MS
Group	Pollution & Environment.		Stack Height: 2.5 Mtr
Sub Group	Stack Emission		Stack Type: Round
Date of Sampling	09/10/2025	Sampling Location	(S61) Fire Engine DG Pump- 100 KVA
Time of Sampling	13:35	Sampling duration	30 Min
Sampling done by	M/s VSK Enviro Solution	Sampling Procedure	CPCB Guideline on methodologies for source emission monitoring
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025
Name of Instrument	Stack Sampling Kit-107	Date of Calibration	08/10/2025
Calibration Certificate No.	SSEC/TH/303	Due Date of Calibration	07/10/2026

Results

Sr. No.	Parameters	Results	Unit(s)	Specifications (MPCB Consent)	Methods
1	Flue Gas Temperature	382	°K	--	--
2	Differential Pressure	3.6	mm WG		
3	Velocity	7.04	M/s		
4	Dimensions of Stack	0.10	Mtr.		
5	Stack Area	0.00785	M ²		
6	Gas Volume	155.20	Nm ³ /Hr		
7	Total Particulate Matter	62.69	mg/Nm ³	≤ 150	IS 11255 (Part 1)
8	Sulphur Dioxide (SO ₂)	37.28	mg/Nm ³	N.S.	IS 11255 (Part 2)
9	Sulphur Dioxide (SO ₂)	0.13	Kg/day	≤ 7.2	IS 11255 (Part 2)
10	Oxides of Nitrogen (NO _x)	12.5	mg/Nm ³	N.S.	IS11255 (PART 7): 2005
11	Acid Mist	ND	mg/Nm ³	N.S.	OSHA 165 SG

Remark.

- All above results are well within MPCB Limit.
- N.S - Not Specified & ND – Not Detected.

Terms and Conditions


- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.


 Reviewed By
 (Ms. Kalyani Gore)




 Authorized Signatory
 (Mr. Abhishek Tope)

*****End of Report*****

Verified By 
 Date: 01.11.25
 Department EHS

Page 1 of 1

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501
Website : www.neetalenvirolab.com, Mob. 8669699854 / 52
Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT

Report No.	NLES/25-26/01/NI/RE/864	Report Issue Date	23/01/2026
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Group	Atmospheric Pollution		
Sub Group	Noise		
Sample Name	DG Insertion Loss Monitoring		
Date of Sampling	14/01/2026		
Method of Sampling	IS 9989: 1981		
Sampling done by	M/s VSK Enviro Solution		
Name of Instrument	Sound Level Meter 06	Date of Calibration	06/05/2025
Calibration Certificate No.	SSEC/ME/156	Due Date of Calibration	05/05/2026

Results

Sr. No.	Description	Test Location	Unit	Reading dB(A)	Insertion loss
1	(S3) D. G. Set-5 (1010 KVA)	Inside Acoustic Enclosure	dB(A)	105.2	27.1
		Outside Acoustic Closure From 0.5 meter away	dB(A)	78.1	
2	(S4) D. G. Set-6 (1010 KVA)	Inside Acoustic Enclosure	dB(A)	106.4	27.5
		Outside Acoustic Closure From 0.5 meter away	dB(A)	78.9	
3	(S5) D. G. Set-7 (1500 KVA)	Inside Acoustic Enclosure	dB(A)	106.8	28.3
		Outside Acoustic Closure From 0.5 meter away	dB(A)	78.5	
4	(S6) D. G. Set-8 (1500 KVA)	Inside Acoustic Enclosure	dB(A)	108.1	27.2
		Outside Acoustic Closure From 0.5 meter away	dB(A)	80.9	


Remark- Maharashtra Pollution Control Board has prescribed in consent, acoustic enclosure/ acoustic treatment of the room should be designed for minimum 25 dB (A) insertion loss or for meeting the ambient noise standard, whichever is on higher side.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.


Reviewed By
(Ms. Kalyani Gore)




Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Verified By
Date: 
06.02.26
Department EHS

Page 1 of 1

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501
Website : www.neetalenvirolab.com, Mob. 8669699854 / 52
Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT

Report No.	NLES/25-26/10/ST/RE/591	Report Issue Date	17/10/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Group	Atmospheric Pollution		
Sub Group	Noise		
Sample Name	DG Insertion Loss Monitoring		
Date of Sampling	09/10/2025		
Method of Sampling	IS 9989: 1981		
Sampling done by	M/s VSK Enviro Solution		
Name of Instrument	Sound Level Meter 06	Date of Calibration	06/05/2025
Calibration Certificate No.	SSEC/ME/156	Due Date of Calibration	05/05/2026

Results

Sr. No.	Description	Test Location	Unit	Reading dB(A)	Insertion loss
1	(S3) D. G. Set-5 (1010 KVA)	Inside Acoustic Enclosure	dB(A)	104.8	28.3
		Outside Acoustic Closure From 0.5 meter away	dB(A)	76.5	
2	(S4) D. G. Set-6 (1010 KVA)	Inside Acoustic Enclosure	dB(A)	106.6	27.0
		Outside Acoustic Closure From 0.5 meter away	dB(A)	79.6	
3	(S5) D. G. Set-7 (1500 KVA)	Inside Acoustic Enclosure	dB(A)	107.9	28.1
		Outside Acoustic Closure From 0.5 meter away	dB(A)	79.8	
4	(S6) D. G. Set-8 (1500 KVA)	Inside Acoustic Enclosure	dB(A)	108.3	27.6
		Outside Acoustic Closure From 0.5 meter away	dB(A)	80.7	

Remark- Maharashtra Pollution Control Board has prescribed in consent, acoustic enclosure/ acoustic treatment of the room should be designed for minimum 25 dB (A) insertion loss or for meeting the ambient noise standard, whichever is on higher side.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

Verified By
Date: *09/10/25*
Department EHS

*****End of Report*****

Page 1 of 1

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :
ISO 9001 : 2015
ISO 14001 : 2015
ISO 45001 : 2018

TEST REPORT (Work Zone Air)

Report No.	NLES/25-26/01/WZ/RE/814	Report Issue Date	23/01/2026
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Date & Time of Sampling	15/01/2026 Time: 10:20
Group	Atmospheric Pollution	Date of receipt of sample in lab	16/01/2026
Sub Group	Work Zone Air	Sampling Procedure	IS 5182 Part 5
Sampling Location	P. P. Area (API-10)	Temperature	26 °C
Wet bulb temperature	18 °C	Relative Humidity	45 %
Sampling done by	M/s VSK Enviro Solution		
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026
Name of Instrument	Handy Sampler 05	Date of Calibration	07/05/2025
Calibration Certificate No.	SSEC/FF/1188	Due Date of Calibration	06/05/2026

Results

Sr. No.	Parameters	Results	Unit(s)	The Factories Act 1948 Standards	Methods
1	Sulphur Dioxide (SO ₂)	0.68	mg/m ³	≤ 10	IS 5182 (Part 2): R2018
2	Nitrogen Oxides (NO ₂)	0.17	mg/m ³	≤ 10	IS 5182 (Part 6): R2018
3	Suspended Particulate Matter	4.6	µg/m ³	NS	NIOSH 0500

Remark- All above results are well within The Factories Act, 1948 Standards. NS – Not Specified.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
Reviewed By
(Ms. Kalyani Gore)



Abhishek
Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Page 1 of 1

Verified By
Date: *06.02.26*
Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :

ISO 9001 : 2015

ISO 14001 : 2015

ISO 45001 : 2018

TEST REPORT (Work Zone Air)

Report No.	NLES/25-26/01/WZ/RE/815	Report Issue Date	23/01/2026
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Date & Time of Sampling	15/01/2026 Time: 10:55
Group	Atmospheric Pollution	Date of receipt of sample in lab	16/01/2026
Sub Group	Work Zone Air	Sampling Procedure	IS 5182 Part 5
Sampling Location	Briquette Boiler – Unloading Area	Temperature	26 °C
Wet bulb temperature	20 °C	Relative Humidity	57 %
Sampling done by	M/s VSK Enviro Solution		
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026
Name of Instrument	Handy Sampler 05	Date of Calibration	07/05/2025
Calibration Certificate No.	SSEC/FF/1188	Due Date of Calibration	06/05/2026

Results

Sr. No.	Parameters	Results	Unit(s)	The Factories Act 1948 Standards	Methods
1	Sulphur Dioxide (SO ₂)	1.04	mg/m ³	≤ 10	IS 5182 (Part 2): R2018
2	Nitrogen Oxides (NO ₂)	0.92	mg/m ³	≤ 10	IS 5182 (Part 6): R2018
3	Suspended Particulate Matter	7.1	µg/m ³	NS	NIOSH 0500


Remark- All above results are well within The Factories Act, 1948 Standards. NS – Not Specified.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.


Reviewed By
(Ms. Kalyani Gore)




Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Page 1 of 1

Verified By 
Date: 06.02.26
Department EHS

Neetal Laboratories And Environmental Services Pvt. Ltd.

Address : H.NO. 43, SANTOSH NAGAR, WAKI BK., TAL. KHED, DIST. PUNE - 410 501

Website : www.neetalenvirolab.com, Mob. 8669699854 / 52

Email: sales@neetalenvirolab.com / neetalenviro@gmail.com

Certifications :

ISO 9001 : 2015

ISO 14001 : 2015

ISO 45001 : 2018

TEST REPORT (Work Zone Air)

Report No.	NLES/25-26/01/WZ/RE/816	Report Issue Date	23/01/2026		
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802				
Discipline	Chemical	Date & Time of Sampling	15/01/2026 Time: 11:30		
Group	Atmospheric Pollution	Date of receipt of sample in lab	16/01/2026		
Sub Group	Work Zone Air	Sampling Procedure	IS 5182 Part 5		
Sampling Location	Fingolimod Area – Ground Floor (API-7)	Temperature	26 °C		
Wet bulb temperature	21 °C	Relative Humidity	63 %		
Sampling done by	M/s VSK Enviro Solution				
Start Date of Analysis	16/01/2026	End Date of Analysis	22/01/2026		
Name of Instrument	Handy Sampler 05	Date of Calibration	07/05/2025		
Calibration Certificate No.	SSEC/FF/1188	Due Date of Calibration	06/05/2026		
Results					
Sr. No.	Parameters	Results	Unit(s)	The Factories Act 1948 Standards	Methods
1	Sulphur Dioxide (SO ₂)	0.93	mg/m ³	≤ 10	IS 5182 (Part 2): R2018
2	Nitrogen Oxides (NO ₂)	0.21	mg/m ³	≤ 10	IS 5182 (Part 6): R2018
3	Suspended Particulate Matter	4.0	µg/m ³	NS	NIOSH 0500
Remark- All above results are well within The Factories Act, 1948 Standards. NS – Not Specified.					

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.


Reviewed By
(Ms. Kalyani Gore)





Authorized Signatory
(Mr. Abhishek Tope)

*****End of Report*****

Page 1 of 1

Verified By

Date:


06.02.26

Department EHS

TEST REPORT (Work Zone Air)

Report No.	NLES/25-26/10/WZ/RE/541	Report Issue Date	17/10/2025		
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802				
Discipline	Chemical	Date & Time of Sampling	09/10/2025 Time: 11:15		
Group	Atmospheric Pollution	Date of receipt of sample in lab	11/10/2025		
Sub Group	Work Zone Air	Sampling Procedure	IS 5182 Part 5		
Sampling Location	P. P. Area (API-10)	Temperature	26 °C		
Wet bulb temperature	19 °C	Relative Humidity	51 %		
Sampling done by	M/s VSK Enviro Solution				
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025		
Name of Instrument	Handy Sampler 05	Date of Calibration	07/05/2025		
Calibration Certificate No.	SSEC/FF/1188	Due Date of Calibration	06/05/2026		
Results					
Sr. No.	Parameters	Results	Unit(s)	The Factories Act 1948 Standards	Methods
1	Sulphur Dioxide (SO ₂)	BDL	mg/m ³	≤ 10	IS 5182 (Part 2): R2018
2	Nitrogen Oxides (NO ₂)	BDL	mg/m ³	≤ 10	IS 5182 (Part 6): R2018
3	Suspended Particulate Matter	5.2	µg/m ³	NS	NIOSH 0500
Remark- All above results are well within The Factories Act, 1948 Standards. NS – Not Specified.					

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
 Reviewed By
 (Ms. Kalyani Gore)



Abhishek
 Authorized Signatory
 (Mr. Abhishek Tope)

*****End of Report*****

Verified By *[Signature]*
 Date: 01.11.25
 Department EHS

TEST REPORT (Work Zone Air)

Report No.	NLES/25-26/10/WZ/RE/542	Report Issue Date	17/10/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Date & Time of Sampling	09/10/2025 Time: 11:55
Group	Atmospheric Pollution	Date of receipt of sample in lab	11/10/2025
Sub Group	Work Zone Air	Sampling Procedure	IS 5182 Part 5
Sampling Location	Briquette Boiler – Unloading Area	Temperature	27 °C
Wet bulb temperature	22 °C	Relative Humidity	65 %
Sampling done by	M/s VSK Enviro Solution		
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025
Name of Instrument	Handy Sampler 05	Date of Calibration	07/05/2025
Calibration Certificate No.	SSEC/FF/1188	Due Date of Calibration	06/05/2026

Results

Sr. No.	Parameters	Results	Unit(s)	The Factories Act 1948 Standards	Methods
1	Sulphur Dioxide (SO ₂)	1.65	mg/m ³	≤ 10	IS 5182 (Part 2): R2018
2	Nitrogen Oxides (NO ₂)	0.86	mg/m ³	≤ 10	IS 5182 (Part 6): R2018
3	Suspended Particulate Matter	6.2	µg/m ³	NS	NIOSH 0500

Remark- All above results are well within The Factories Act, 1948 Standards. NS – Not Specified.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.

Kalyani
 Reviewed By
 (Ms. Kalyani Gore)



Abhishek
 Authorized Signatory
 (Mr. Abhishek Tope)

*****End of Report*****

Verified By *B*
 Date: *01.11.25*
 Department EHS

TEST REPORT (Work Zone Air)

Report No.	NLES/25-26/10/WZ/RE/543	Report Issue Date	17/10/2025
Name and Address of Customer	M/s EMCURE PHARMACEUTICALS LTD., Plot. No. D-24, MIDC Kurkumbh, Tal. Daund, Dist. Pune. 413 802		
Discipline	Chemical	Date & Time of Sampling	09/10/2025 Time: 11:35
Group	Atmospheric Pollution	Date of receipt of sample in lab	11/10/2025
Sub Group	Work Zone Air	Sampling Procedure	IS 5182 Part 5
Sampling Location	Fingolimod Area – Ground Floor (API-7)	Temperature	26 °C
Wet bulb temperature	22 °C	Relative Humidity	71 %
Sampling done by	M/s VSK Enviro Solution		
Start Date of Analysis	11/10/2025	End Date of Analysis	16/10/2025
Name of Instrument	Handy Sampler 05	Date of Calibration	07/05/2025
Calibration Certificate No.	SSEC/FF/1188	Due Date of Calibration	06/05/2026

Results

Sr. No.	Parameters	Results	Unit(s)	The Factories Act 1948 Standards	Methods
1	Sulphur Dioxide (SO ₂)	BDL	mg/m ³	≤ 10	IS 5182 (Part 2): R2018
2	Nitrogen Oxides (NO ₂)	BDL	mg/m ³	≤ 10	IS 5182 (Part 6): R2018
3	Suspended Particulate Matter	3.2	µg/m ³	NS	NIOSH 0500

Remark- All above results are well within The Factories Act, 1948 Standards. NS – Not Specified.

Terms and Conditions

- This Report is valid for tested sample only
- The test report cannot be reproduced wholly or in part and cannot be used for promotional or publicity purpose without the written consent of laboratory, NLES.



 Reviewed By
 (Ms. Kalyani Gore)




 Authorized Signatory
 (Mr. Abhishek Tope)

*****End of Report*****

Page 1 of 1

Verified By
 Date: 
 Department EHS